

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **2/2024**

System Name: **Camp Tapawingo** **ID#: 41** **91259** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1				0.88			
2						PO	
3						PO	
4				0.62			
5						PO	
6						PO	
7						PO	
8						PO	
9						PO	
10				0.49			
11						PO	
12						PO	
13						PO	
14						PO	
15						PO	
16				0.68			
17						PO	
18						PO	
19						PO	
20						PO	
21						PO	
22						PO	
23					0.28		
24				0.54			
25						PO	
26						PO	
27						PO	
28						PO	
29						PO	
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 2/2024

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/11.04am	2	49	98.0	9.7	7.50	52.6	Yes	0.7
2		49						1.2
3		49						0.8
4/11.48am	1.8	49	88.2	10.4	7.40	47.3	Yes	0.5
5		49						0.8
6		49						1.3
7		49						1.3
8		49						0.8
9		49						1
10/10.18am	1.8	49	88.2	10.2	7.30	46.3	Yes	2.5
11		49						0.3
12		49						0.7
13		49						0.7
14		49						0.8
15		49						1.2
16/11.48am	1.8	49	88.2	10.6	7.30	45.1	Yes	2.8
17		49						8.3
18		49						8.3
19		49						5.8
20		49						1.5
21		49						0.3
22		49						0.7
23/4.48pm	1.8	49	88.2	11.4	7.40	44.3	Yes	1.3
24/11.21am	2	49	98.0	8.7	7.40	54.2	Yes	3
25		49						3.5
26		49						1
27		49						0.3
28		49						0.5
29		49						0.3
30		49						
31		49						