

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **3/2024**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1						PO	
2						PO	
3						PO	
4						PO	
5						PO	
6						PO	
7					0.36		
8					0.32		
9						PO	
10						PO	
11						PO	
12				0.73			
13						PO	
14						PO	
15					0.57		
16					0.42		
17						PO	
18						PO	
19						PO	
20						PO	
21						PO	
22						PO	
23						PO	
24						PO	
25						PO	
26				0.23			
27						PO	
28						PO	
29						PO	
30						PO	
31						PO	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	Yes	Yes

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: **Camp Tapawingo**

ID#: **41 91259**

Month/Year: **3/2024**

Disinfection *Giardia* Log Inactiv: **1.0**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						1
2		49						2
3		49						0.7
4		49						0.5
5		49						1
6		49						0.8
7/5.02pm	1.4	49	68.6	11.0	7.40	43.5	Yes	0.5
8/3.33pm	1.6	49	78.4	11.6	7.40	42.7	Yes	4.3
9		49						0.3
10		49						0.5
11		49						0.5
12/1.52pm	2	49	98.0	8.7	7.40	54.2	Yes	0.5
13		49						0.5
14		49						0.7
15/2.43pm	1.8	49	88.2	12.4	7.40	41.5	Yes	2.7
16/4.48pm	1.8	49	88.2	12.8	7.40	40.1	Yes	3
17		49						1.5
18		49						0.5
19		49						1.5
20		49						1.3
21		49						3.2
22		49						2.8
23		49						2.7
24		49						0.2
25		49						0.8
26/10.41am	1.8	49	88.2	10.2	7.30	46.3	Yes	0.8
27		49						0.8
28		49						0.2
29		49						0.8
30		49						0.5
31		49						0.7