

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **4/2024**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					PO		
2					PO		
3					PO		
4				0.44			
5					PO		
6					PO		
7					PO		
8					PO		
9					PO		
10					PO		
11					PO		
12					PO		
13				0.36			
14					PO		
15					PO		
16					PO		
17			0.34				
18					PO		
19					PO		
20					PO		
21					PO		
22					PO		
23						0.28	
24					PO		
25					PO		
26					PO		
27					PO		
28					PO		
29					PO		
30					PO		
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	Yes	Yes

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: Apr-24

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						0.8
2		49						1
3		49						1.2
4/10.03pm	1.8	49	88.2	12.2	7.30	40.6	Yes	0.7
5		49						3.5
6		49						3.3
7		49						2.8
8		49						1.3
9		49						1
10		49						0.7
11		49						1.8
12		49						1.5
13/1.12pm	1.8	49	88.2	12.4	7.30	40.0	Yes	1
14		49						0.5
15		49						3.2
16		49						1.7
17/9.33am	1.8	49	88.2	10.2	7.40	48.0	Yes	0.8
18		49						1
19		49						2
20		49						3.3
21		49						2.7
22		49						4
23/6.08pm	1.8	49	88.2	13.0	7.40	39.5	Yes	8.3
24		49						0.8
25		49						0.8
26		49						1.2
27		49						2.3
28		49						1.2
29		49						3
30		49						5.3
31		49						