

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **5/2024**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1				PO			
2				PO			
3				PO			
4				PO			
5				PO			
6				PO			
7				PO			
8					0.33		
9				PO			
10					0.27		
11				PO			
12				PO			
13				PO			
14				PO			
15				PO			
16					0.24		
17			0.20				
18				PO			
19				PO			
20				PO			
21				PO			
22				PO			
23				PO			
24					0.17		
25				PO			
26					0.28		
27				PO			
28				PO			
29				PO			
30				PO			
31			0.38				

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: May-24

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						5
2		49						2.7
3		49						1.2
4		49						1.2
5		49						0.5
6		49						2.7
7		49						3.2
8/4.48pm	1.2	49	58.8	15.4	7.20	29.2	Yes	3.2
9		49						1.3
10/5.11pm	1.2	49	58.8	16.2	7.30	28.7	Yes	2.7
11		49						4.5
12		49						2.5
13		49						5
14		49						2
15		49						3.2
16/4.12pm	1.6	49	78.4	15.6	7.30	31.3	Yes	2.8
17/9.22am	1.8	49	88.2	12.4	7.30	40.0	Yes	6.2
18		49						0.8
19		49						0.7
20		49						3.3
21		49						1.8
22		49						6.2
23		49						4
24/5.14pm	1.6	49	78.4	16.3	7.40	31.0	Yes	4
25		49						4.3
26/4.48pm	1.6	49	78.4	16.1	7.40	31.4	Yes	7
27		49						3.2
28		49						4
29		49						3.8
30		49						5.5
31/9.03am	1.8	49	88.2	12.6	7.40	40.6	Yes	4.3