

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **6/2024**

System Name: **Camp Tapawingo** **ID#: 41** **91259** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					PO		
2					PO		
3					PO		
4					PO		
5					PO		
6					PO		
7			0.32				
8					PO		
9					PO		
10					PO		
11				0.26			
12					PO		
13				0.28			
14					PO		
15					PO		
16					PO		
17					PO		
18					PO		
19					0.19		
20					PO		
21					PO		
22					PO		
23					0.28		
24			0.18				
25					0.27		
26					PO		
27					0.32		
28				0.37			
29					PO		
30				0.42			
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo ID#: 41 91259 Month/Year: 6/2024

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						1.2
2		49						0.8
3		49						3.5
4		49						3.5
5		49						1.2
6		49						2.5
7/8.22am	1.6	49	78.4	14.7	7.40	34.5	Yes	4.6
8		49						1.7
9		49						3
10		49						5
11/11.31am	1.6	49	78.4	16.0	7.40	31.6	Yes	5.5
12		49						5
13/11.28am	1.4	49	68.6	15.5	7.20	29.7	Yes	3.7
14		49						3
15		49						0.8
16		49						0.8
17		49						1.2
18		49						0.5
19/4.09pm	1.4	49	68.6	20.2	7.40	23.3	Yes	4.6
20		49						4.3
21		49						2.8
22		49						1.7
23/4.45pm	1.6	49	78.4	17.8	7.40	28.1	Yes	6.5
24/9.41am	1.8	49	88.2	16.3	7.30	30.6	Yes	6.8
25/3.53pm	1.8	49	88.2	20.5	7.40	24.0	Yes	7.5
26		49						5.6
27/4.58pm	1.8	49	88.2	19.8	7.30	24.2	Yes	6.8
28/12.18pm	1.6	49	78.4	18.5	7.10	23.9	Yes	6
29		49						3.8
30/12.45pm	1.6	49	78.4	22.4	7.20	19.1	Yes	6
31		49						