

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **7-2024**

**System Name:** **Camp Tapawingo**      **ID#: 41**      **91259**      **WTP : TP -**      **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1				0.44			
2					0.68		
3			0.37				
4				0.51			
5					0.31		
6					0.34		
7					0.28		
8					0.37		
9				0.32			
10					0.24		
11			0.27				
12			0.26				
13					0.43		
14			0.32				
15				0.35			
16				0.26			
17			0.17				
18					0.28		
19				0.26			
20				0.26			
21			0.24				
22					0.21		
23				0.26			
24				0.32			
25				0.24			
26				0.43			
27					PO		
28					PO		
29					PO		
30					PO		
31				0.28			

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

**WTP - : A**

**System Name: Camp Tapawingo**

**ID#: 41 91259**

**Month/Year: 7-2024**

**Disinfection *Giardia* Log Inactiv: 1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1/10.32am	1.6	49	78.4	18.8	7.10	23.5	Yes	
2/3.41pm	1.6	49	78.4	18.2	7.10	24.4	Yes	
3/9.48am	1.6	49	78.4	14.5	7.10	31.3	Yes	
4/1.51pm	2	49	98.0	21.0	7.20	22.0	Yes	
5/2.38pm	2	49	98.0	20.1	7.30	24.3	Yes	
6/3.46pm	1.6	49	78.4	27.7	7.30	13.8	Yes	
7/2.52pm	1.8	49	88.2	27.2	7.30	14.6	Yes	
8/2.53pm	1.8	49	88.2	27.4	7.30	14.4	Yes	
9/11.07am	1.6	49	78.4	18.9	7.30	25.1	Yes	
10/3.24pm	2	49	98.0	26.2	7.30	16.1	Yes	
11/9.42am	2	49	98.0	18.7	7.30	26.6	Yes	
12/9.22am	2	49	98.0	17.5	7.30	28.9	Yes	
13/2.00pm	2.2	49	107.8	24.5	7.30	18.4	Yes	
14/7.41am	2	49	98.0	15.2	7.30	33.7	Yes	
15/11.55am	2.2	49	107.8	20.4	7.30	24.3	Yes	
16/10.50am	2.2	49	107.8	19.7	7.30	25.5	Yes	
17/9.58am	2	49	98.0	18.7	7.30	26.6	Yes	
18/5.18pm	2	49	98.0	19.2	7.30	25.8	Yes	
19/2.31pm	2	49	98.0	18.9	7.30	26.3	Yes	
20/10.05am	2	49	98.0	17.6	7.20	27.6	Yes	
21/9.07am	2	49	98.0	16.6	7.30	30.7	Yes	
22/3.24pm	2	49	98.0	19.1	7.20	25.0	Yes	
23/12.01pm	2	49	98.0	18.4	7.30	27.2	Yes	
24/11.53am	2	49	98.0	18.8	7.20	25.5	Yes	
25/11.51am	2	49	98.0	17.3	7.30	29.3	Yes	
26/12.14pm	2.2	49	107.8	17.2	7.30	30.1	Yes	
27		49						
28		49						
29		49						
30		49						
31/11.44am	2	49	98.0	18.6	7.30	26.8	Yes	