

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **8/2024**

System Name: **Camp Tapawingo** **ID#: 41** **91259** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.25				
2			0.28				
3			0.29				
4			0.23				
5				0.34			
6				0.28			
7			0.29				
8			0.20				
9				0.25			
10				0.24			
11					0.22		
12						PO	
13						PO	
14						PO	
15						PO	
16						PO	
17						PO	
18						PO	
19					0.24		
20			0.26				
21			0.32				
22			0.19				
23				0.23			
24						PO	
25						PO	
26						PO	
27						PO	
28						PO	
29						PO	
30						PO	
31						PO	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo ID#: 41 91259 Month/Year: 8/2024

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/9.13AM	2	49	98.0	19.4	7.30	25.4	Yes	6.3
2/12.15PM	2	49	98.0	19.2	7.30	25.8	Yes	10.6
3/11.41AM	2	49	98.0	19.8	7.40	25.7	Yes	7
4/11.13AM	2	49	98.0	20.0	7.40	25.4	Yes	8.3
5/12.18PM	2	49	98.0	20.8	7.40	24.0	Yes	7.7
6/12.31PM	2	49	98.0	20.6	7.30	23.5	Yes	8.3
7/9.11AM	1.8	49	88.2	17.4	7.30	28.4	Yes	8.3
8/9.34AM	2	49	98.0	18.3	7.50	29.5	Yes	7.5
9/11.56AM	2	49	98.0	18.2	7.50	29.7	Yes	7.5
10/1.12PM	2	49	98.0	19.6	7.40	26.0	Yes	4.5
11/3.08PM	2	49	98.0	18.8	7.40	27.5	Yes	2.2
12		49						5.3
13		49						3
14		49						0.3
15		49						1.3
16		49						2.3
17		49						3.7
18		49						1.2
19/4.07PM	2	49	98.0	20.3	7.40	24.8	Yes	5.5
20/8.15AM	2	49	98.0	17.0	7.40	31.0	Yes	6.3
21/8.14AM	2	49	98.0	16.8	7.30	30.3	Yes	6
22/8.18AM	2	49	98.0	16.2	7.30	31.5	Yes	6.7
23/10.48AM	1.8	49	88.2	16.8	7.40	30.7	Yes	5.5
24		49						1.3
25		49						3.3
26		49						1.2
27		49						2.3
28		49						4
29		49						1.8
30		49						1.8
31		49						1.8