

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **9/2024**

System Name: **Camp Tapawingo** ID#: **41 91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1					PO		
2					PO		
3					PO		
4					PO		
5					PO		
6				0.44			
7					PO		
8					PO		
9					PO		
10					PO		
11					PO		
12			0.20				
13					PO		
14					PO		
15				0.37			
16				0.49			
17					PO		
18					PO		
19					PO		
20				0.34			
21					0.32		
22				0.30			
23			0.46				
24			0.21				
25					PO		
26					PO		
27					PO		
28					PO		
29					PO		
30					PO		
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

WTP- : A

System Name: **Camp Tapawingo**

ID#: **41 91259**

Month/Year: **9/2024**

Disinfection *Giardia* Log  
Inactiv: **1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1		49						1.2
2		49						0.5
3		49						4
4		49						2.3
5		49						5
6/11.50am	1.8	49	88.2	21.3	7.30	21.9	Yes	1.8
7		49						1.3
8		49						2.5
9		49						3.7
10		49						0.7
11		49						4.5
12/8.46am	1.8	49	88.2	16.2	7.30	30.8	Yes	4.3
13		49						0.7
14		49						3.2
15/10.40am	1.8	49	88.2	15.9	7.40	32.6	Yes	4
16/12.09pm	1.8	49	88.2	15.4	7.40	33.7	Yes	3.2
17		49						0.5
18		49						error
19		49						error
20/11.40am	1.6	49	78.4	14.4	7.10	31.5	Yes	error
21/3.25pm	1.8	49	88.2	14.9	7.20	32.4	Yes	error
22/10.02am	1.8	49	88.2	14.7	7.20	32.8	Yes	3
23/9.17am	2.2	49	107.8	15.4	7.40	35.3	Yes	5.8
24/9.09am	2.2	49	107.8	18.0	7.40	29.7	Yes	9
25		49						0.7
26		49						1.2
27		49						1.2
28		49						1.5
29		49						0.7
30/2.51pm	2	49	98.0	17.2	7.40	30.6	Yes	1.3
31		49						