

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **10/2024**

**System Name:** **Camp Tapawingo**      **ID#: 41**      **91259**      **WTP : TP -**      **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1					0.24		
2				0.20			
3						PO	
4						PO	
5						PO	
6						PO	
7						PO	
8						PO	
9						PO	
10						PO	
11				0.37			
12				0.24			
13			0.32				
14						PO	
15					0.30		
16				0.18			
17						PO	
18					0.23		
19				0.41			
20						PO	
21						PO	
22						PO	
23						PO	
24						PO	
25				0.52			
26						PO	
27						PO	
28						PO	
29						PO	
30					0.48		
31						PO	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

**WTP - : A**

**System Name: Camp Tapawingo ID#: 41 91259 Month/Year: Oct-24 Disinfection *Giardia* Log Inactiv: 1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1/2.25pm	2	49	98.0	15.8	7.30	32.3	Yes	2.7
2/1.29pm	2	49	98.0	13.6	7.20	36.1	Yes	1.3
3		49						1.2
4		49						1.5
5		49						3
6		49						2.5
7		49						0.7
8		49						11.7
9		49						3.7
10		49						0.7
11/1.41pm	1.8	49	88.2	14.4	7.50	37.4	Yes	3.7
12/1.39pm	2.2	49	107.8	14.9	7.50	37.8	Yes	3.8
13/9.55am	2.4	49	117.6	13.3	7.40	41.5	Yes	1.7
14		49						2.3
15/4.09pm	1.6	49	78.4	19.6	7.30	24.0	Yes	4.2
16/11.11am	1.8	49	88.2	19.5	7.40	25.6	Yes	3.3
17/4.56pm	1.8	49	88.2	15.2	7.30	32.9	Yes	2.7
18/10.11am	1.6	49	78.4	16.6	7.40	30.4	Yes	3.3
19		49						4.5
20		49						4.2
21		49						3.7
22		49						0.2
23		49						1
24		49						1
25		49						3
26/10.12am	1.8	49	88.2	15.8	7.30	31.6	Yes	5.3
27		49						3.2
28		49						1
29		49						1
30/4.48pm	2	49	98.0	16.0	7.30	31.9	Yes	1.7
31		49						1