

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **12/2024**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					0.21		
2							
3							
4							
5							
6							
7							
8							
9				0.43			
10							
11							
12							
13							
14							
15							
16				0.69			
17							
18							
19				0.30			
20							
21							
22					0.67		
23				0.42			
24				0.31			
25				0.33			
26							
27							
28							
29			0.46				
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo ID#: 41 91259 Month/Year: 12/2024

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/4.59pm	0.8	49	39.2	13.6	7.20	31.5	Yes	1.2
2		49						0.7
3		49						1.2
4		49						0.8
5		49						0.7
6		49						1
7		49						0.5
8		49						0.8
9/10.54am	2	49	98.0	11.4	7.20	42.2	Yes	1.2
10		49						1
11		49						0.8
12		49						1
13		49						0.7
14		49						1.3
15		49						1.5
16/11.11am	1.8	49	88.2	10.8	7.30	44.5	Yes	0.8
17		49						1.5
18		49						0.5
19/10.13am	2	49	98.0	9.9	7.50	51.9	Yes	1
20		49						0.7
21		49						0.8
22/3.54pm	1.8	49	88.2	11.9	7.30	41.4	Yes	0.2
23/11.50am	2	49	98.0	10.1	7.50	51.2	Yes	0.8
24/10.39am	2	49	98.0	10.3	7.40	48.7	Yes	1.5
25/11.10am	2	49	98.0	10.2	7.30	47.4	Yes	1
26		49						0.3
27		49						1.2
28		49						1.7
29/9.49am	1.6	49	78.4	10.0	7.00	41.3	Yes	0.7
30		49						1
31		49						1.2