

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Polk
Month/Year: 1/2025

System Name: Camp Tapawingo		ID#: 41 91259		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1						PO	
2						PO	
3						PO	
4						PO	
5						PO	
6				0.42			
7						PO	
8						PO	
9						PO	
10					0.34		
11						PO	
12						PO	
13				0.23			
14						PO	
15						PO	
16						PO	
17					0.55		
18				0.23			
19				0.22			
20						PO	
21						PO	
22				0.26			
23						PO	
24					0.19		
25						PO	
26						PO	
27					0.15		
28						PO	
29						PO	
30						PO	
31						PO	

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
Notes:		PRINTED NAME: Brad Schmidt	
		PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo ID#: 41 91259 Month/Year: 1/2025

Disinfection *Giardia* Log
Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						1.3
2		49						0.8
3		49						1.1
4		49						1
5		49						0.3
6/11.58 AM	1.6	49	78.4	9.8	7.30	46.5	Yes	1.3
7		49						1
8		49						1.2
9		49						0.5
10/3.16 PM	1.6	49	78.4	10.6	7.30	44.1	Yes	0.8
11		49						1.7
12		49						1.2
13/10.53 AM	1.4	49	68.6	10.2	7.40	45.8	Yes	1
14		49						0.7
15		49						0.7
16		49						1
17/2.22 PM	2.2	49	107.8	7.8	7.30	56.9	Yes	4.3
18/11.14 AM	2.4	49	117.6	8.8	7.20	52.5	Yes	6.3
19/10.47 AM	2.6	49	127.4	8.7	7.40	58.1	Yes	6.6
20		49						4.3
21		49						4.8
22/11.40 AM	2	49	98.0	8.0	7.00	49.3	Yes	3.7
23		49						1.3
24/3.45 PM	2.4	49	117.6	11.1	7.30	46.7	Yes	2.5
25		49						4.5
26		49						5.1
27/2.57 PM	2	49	98.0	7.5	7.00	51.0	Yes	1.8
28		49						0.8
29		49						1
30		49						1.3
31		49						1