

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Polk
Month/Year: 2/2025

System Name: Camp Tapawingo		ID#: 41		91259		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					PO		
2					PO		
3					PO		
4					PO		
5					PO		
6					0.28		
7					PO		
8					PO		
9					PO		
10					PO		
11				0.22			
12					PO		
13					PO		
14					PO		
15					PO		
16					0.36		
17					PO		
18					PO		
19					PO		
20					PO		
21					0.42		
22					0.33		
23					PO		
24					PO		
25					PO		
26					PO		
27					0.24		
28					PO		
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
Notes:		PRINTED NAME: Brad Schmidt	
		SIGNATURE:	DATE:
		PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- : A
System Name: Camp Tapawingo ID#: 41 91259 Month/Year: Feb-25
Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		170						0.73
2		170						1.27
3		170						0.54
4		170						1.09
5		170						0.73
6 - 4.13p	1.6	170	272.0	9.8	7.20	44.9	Yes	1.45
7		170						0.91
8		170						0.91
9		170						1.09
10		170						0.54
11 - 11.58a	1.8	170	306.0	9.6	7.10	44.9	Yes	0.91
12		170						0.91
13		170						1.27
14		170						1.45
15		170						1.27
16-3.28p	1.6	170	272.0	9.8	7.20	44.9	Yes	0.91
17		170						0.73
18		170						1.81
19		170						1.27
20		170						1.09
21-5.15p	1.6	170	272.0	10.6	7.30	44.1	Yes	3.45
22-3.41p	1.8	170	306.0	10.4	7.30	45.7	Yes	5.26
23		170						3.26
24		170						1.27
25		170						0.54
26		170						1.09
27-3.37p	1.6	170	272.0	11.8	7.30	40.7	Yes	1.27
28		170						1.09
29		170						
30		170						
31		170						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013