

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **April 2025**

System Name: Camp Tapawingo		ID#: 41		91259		WTP : TP -		A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1						po		
2					0.24			
3						po		
4						po		
5						po		
6				0.51				
7						po		
8						po		
9						po		
10						po		
11			0.57					
12						po		
13						po		
14					0.46			
15						po		
16						po		
17						po		
18						po		
19						po		
20					0.44			
21						po		
22						po		
23						po		
24						po		
25						po		
26						po		
27				0.17				
28						po		
29			0.47					
30			0.22					
31								

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes		CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes			
Notes:		PRINTED NAME: Brad Schmidt	
		SIGNATURE:	DATE:
		PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo ID#: 41 91259 Month/Year: Apr-25 Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		170						1.27
2-2.13	1	170	170.0	10.9	7.00	36.4	Yes	0.54
3		170						1.09
4		170						2.36
5		170						3.45
6-10.02	2	170	340.0	10.8	7.00	41.0	Yes	3.08
7		170						0.91
8		170						1.09
9		170						0.73
10		170						1.45
11-9.03	1.8	170	306.0	10.3	7.00	41.4	Yes	1.27
12		170						2.18
13		170						2.18
14-3.00	2.2	170	374.0	16.0	7.00	29.2	Yes	2.54
15		170						3.99
16		170						0.91
17		170						0.91
18		170						6.53
19		170						1.45
20-4.28	1.8	170	306.0	12.6	7.00	35.0	Yes	0.54
21		170						0.54
22		170						1.81
23		170						1.09
24		170						9.25
25		170						1.45
26		170						8.34
27-10.24	2.2	170	374.0	10.4	7.00	43.0	Yes	2.72
28		170						3.81
29-9.12	2.2	170	374.0	11.8	7.00	39.2	Yes	4.17
30-9.11	2	170	340.0	9.6	7.00	44.3	Yes	4.72
31		170						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013