

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Polk
Month/Year: May/2025

System Name: Camp Tapawingo		ID#: 41		91259		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					0.23		3.45
2						po	4.35
3					0.22		5.26
4					0.37		9.98
5						po	4.72
6						po	6.53
7						po	0.91
8						po	8.71
9						po	1.45
10						po	0.73
11						po	4.17
12						po	1.09
13				0.53			1.63
14					0.18		5.62
15				0.56			7.07
16			0.64				5.62
17						po	0.73
18						po	1.63
19			0.31				4.35
20						po	3.45
21					0.61		5.44
22						po	2.00
23			0.26				3.08
24			0.21				9.98
25				0.24			6.71
26			0.24				5.44
27					0.22		8.34
28						po	3.63
29						po	4.17
30						po	10.88
31						po	2.18

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	SIGNATURE:	DATE:
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP - : A
System Name: Camp Tapawingo ID#: 41 91259 Month/Year: May-25
Disinfection *Giardia* Log
Inactiv: 1.0

Date / Time	minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-3.23p	2.2	170	374.0	18.0	7.00	25.6	Yes	
2		170						
3-5.42p	2	170	340.0	15.8	7.00	28.9	Yes	
4-3.55p	2	170	340.0	16.2	7.00	28.2	Yes	
5		170						
6		170						
7		170						
8		170						
9		170						
10		170						
11		170						
12		170						
13-1.40p	1.4	170	238.0	16.7	7.00	25.4	Yes	
14-2.49p	1.8	170	306.0	14.2	7.10	32.7	Yes	
15-12.52p	2	170	340.0	13.2	7.20	37.1	Yes	
16-9.34a	2	170	340.0	12.2	7.00	37.4	Yes	
17		170						
18		170						
19-1.42p	2	170	340.0	13.6	7.00	33.5	Yes	
20		170						
21-3.50p	2.2	170	374.0	17.4	7.00	26.6	Yes	
22		170						
23		170						
24-9.44a	2	170	340.0	16.2	7.00	28.2	Yes	
25-1.30p	2	170	340.0	15.4	7.20	32.0	Yes	
26-10.52a	2	170	340.0	15.2	7.10	31.3	Yes	
27-8.43a	1.6	170	272.0	11.8	7.20	39.3	Yes	
28-3.30p	2	170	340.0	18.7	7.00	23.8	Yes	
29		170						
30		170						
31		170						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013