

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **June 2025**

System Name: Camp Tapawingo		ID#: 41		91259		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1						po	
2						po	
3						po	
4						po	
5						po	
6					0.32		
7						po	
8						po	
9					0.24		
10						po	
11				0.22			
12						po	
13						po	
14						po	
15						po	
16						po	
17						po	
18					0.28		
19					0.16		
20						po	
21						po	
22						po	
23				0.23			
24					0.17		
25					0.21		
26					0.34		
27						po	
28						po	
29						po	
30				0.37			
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes		CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes			
Notes:		PRINTED NAME: Brad Schmidt	
		SIGNATURE:	DATE:
		PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP - : A
System Name: Camp Tapawingo ID#: 41 91259 Month/Year: Jun-25
Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		170						0.73
2		170						8.89
3		170						2.72
4		170						7.25
5		170						2.9
6-5.14p	2	170	340.0	15.6	7.20	31.6	Yes	2
7		170						3.26
8		170						2
9-4.33p	2.2	170	374.0	23.2	7.00	18.0	Yes	5.44
10		170						4.9
11-11.42a	2.2	170	374.0	16.5	7.00	28.3	Yes	12.51
12		170						2.54
13		170						10.7
14		170						2
15		170						2.54
16		170						7.07
17		170						4.35
18-4.38p	2.2	170	374.0	19.2	7.00	23.6	Yes	7.44
19-2.58p	2.2	170	374.0	18.9	7.10	25.0	Yes	6.71
20		170						7.25
21		170						4.9
22		170						1.63
23-11.43	2.4	170	408.0	14.6	7.00	32.8	Yes	4.17
24-3.48p	2.4	170	408.0	21.4	7.20	22.4	Yes	9.79
25-3.02p	2.6	170	442.0	17.8	7.20	29.2	Yes	6.89
26-5.02p	2.2	170	374.0	19.0	6.90	23.0	Yes	5.8
27		170						10.7
28		170						5.8
29		170						0.91
30-1.17	2	170	340.0	20.1	7.10	22.5	Yes	8.71
31		170						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013