

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **08/2025**

System Name: Camp Tapawingo		ID#: 41		91259		WTP : TP -		A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1				0.22				
2				0.17				
3						0.30		
4						po		
5						po		
6						po		
7						po		
8			0.24					
9						0.24		
10					0.27			
11					0.22			
12			0.30					
13						po		
14						po		
15						0.78		
16					0.28			
17						0.37		
18					0.20			
19				0.21				
20						po		
21						po		
22				0.28				
23				0.19				
24				0.20				
25				0.32				
26				0.19				
27						po		
28				0.26				
29						0.34		
30					0.19			
31						po		

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes		CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes			
Notes:		PRINTED NAME: Brad Schmidt	
		PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name:	Camp Tapawingo	ID#: 41	91259	Month/Year: Aug-25	Disinfection <i>Giardia</i> Log Inactiv:	1.0
--------------	----------------	---------	-------	--------------------	--	-----

Date / Time	minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1-12.08a	2.2	49	107.8	19.6	7.20	24.7	Yes	4.35
2-1.58p	2	49	98.0	19.4	7.20	24.5	Yes	3.45
3-7.02a	2.2	49	107.8	23.0	7.30	20.4	Yes	6.71
4		49						1.27
5		49						6.71
6		49						3.26
7		49						4.35
8-8.01a	2.2	49	107.8	17.8	7.20	27.9	Yes	5.99
9-8.03a	2.2	49	107.8	23.6	7.10	18.2	Yes	7.98
10-5.01p	2.2	49	107.8	22.7	7.10	19.3	Yes	11.61
11-5.04p	2.2	49	107.8	22.4	7.20	20.5	Yes	6.71
12-9.02a	2.4	49	117.6	17.4	7.20	29.3	Yes	4.9
13		49						1.81
14		49						6.89
15-8.31p	2.4	49	117.6	29.1	7.30	13.8	Yes	6.71
16-4.39p	2.2	49	107.8	27.9	7.20	14.1	Yes	9.79
17-7.44p	2.2	49	107.8	25.4	7.20	16.7	Yes	7.62
18-5.17p	2.4	49	117.6	26.2	7.20	16.2	Yes	6.17
19-12.57p	2.4	49	117.6	19.7	7.30	26.1	Yes	7.62
20		49						2
21		49						6.17
22-11.01a	2.2	49	107.8	16.9	7.00	27.5	Yes	7.62
23-1.06p	2.4	49	117.6	20.4	6.90	21.4	Yes	8.34
24-11.57a	2.2	49	107.8	19.2	7.00	23.6	Yes	8.52
25-11.44a	2.2	49	107.8	18.0	7.10	26.5	Yes	10.34
26-1.26p	2	49	98.0	20.8	7.10	21.5	Yes	7.62
27		49						3.45
28-11.20a	2	49	98.0	16.9	7.00	26.9	Yes	8.71
29-6.02p	2.2	49	107.8	26.0	7.00	14.9	Yes	9.07
30-4.58p	2.2	49	107.8	24.2	7.10	17.5	Yes	12.88
31		49						7.25