

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **08/2025**

System Name: Camp Tapawingo		ID#: 41		91259		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1						po	
2						po	
3					0.18		
4					0.16		
5					0.20		
6						0.34	
7						0.26	
8			0.32				
9			0.28				
10						po	
11						po	
12						po	
13				0.24			
14					0.17		
15					0.20		
16						po	
17						po	
18						0.14	
19					0.21		
20					0.22		
21					0.17		
22						po	
23						po	
24						po	
25						po	
26						po	
27						po	
28					0.27		
29					0.47		
30						po	
31						po	

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes	Yes	Yes
Notes:		PRINTED NAME: Brad Schmidt	
		PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo ID#: 41 91259 Month/Year: 08/2025

Disinfection *Giardia* Log

Inactiv:

1.0

Date / Time	minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						7.81
2		49						1.33
3-2.35p	2.2	49	107.8	18.6	7.10	25.5	Yes	4.32
4-3.01p	2	49	98.0	18.9	7.00	23.5	Yes	6.15
5-5.04p	2.2	49	107.8	23.1	7.00	18.1	Yes	12.14
6-6.23p	2	49	98.0	22.4	6.90	17.9	Yes	9.31
7-6.08p	2	49	98.0	19.2	7.00	23.0	Yes	12.8
8-8.25p	2.2	49	107.8	15.3	6.90	29.5	Yes	11.97
9-9.44a	2	49	98.0	16.8	7.00	27.1	Yes	8.31
10		49						1.16
11		49						4.49
12		49						4.99
13-12.09p	2	49	98.0	22.0	7.20	20.6	Yes	4.66
14-2.32p	2.2	49	107.8	23.1	7.00	18.1	Yes	6.15
15-2.34p	2.4	49	117.6	20.8	7.00	21.7	Yes	5.49
16		49						4.16
17		49						2.99
18-7.08p	2.4	49	117.6	22.5	7.00	19.3	Yes	6.15
19-4.55p	2.4	49	117.6	23.7	7.00	17.8	Yes	8.15
20-4.58p	2.4	49	117.6	23.4	7.00	18.2	Yes	8.48
21-4.11p	2.4	49	117.6	23.5	7.00	18.0	Yes	7.48
22		49						8.48
23		49						1
24		49						2
25		49						4.49
26		49						0.17
27		49						1.33
28-2.02p	1.8	49	88.2	22.3	7.00	18.3	Yes	1.66
29-3.11p	1.6	49	78.4	20.6	7.00	20.0	Yes	5.32
30		49						1
31		49						3.66