

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **September 2025**

System Name: Camp Tapawingo		ID#: 41 91259		WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1						po	
2						po	
3						po	
4						0.24	
5				0.60			
6						po	
7						po	
8			0.24				
9						po	
10					0.24		
11						po	
12						po	
13						0.51	
14						po	
15				0.53			
16						po	
17			0.34				
18			0.24				
19						po	
20				0.28			
21						po	
22						po	
23						po	
24			0.15				
25						po	
26						po	
27						po	
28						po	
29					0.44		
30						po	
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes		CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes			
Notes:		PRINTED NAME: Brad Schmidt	
		SIGNATURE:	DATE:
		PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP - : A
System Name: Camp Tapawingo **ID#: 41 91259** **Month/Year:** **Disinfection *Giardia* Log Inactiv:** 1.0

Date / Time	minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		170						1
2		170						6.48
3		170						1
4-8.32p	1.8	170	306.0	17.1	7.00	25.9	Yes	3.49
5-11.52a	1.8	170	306.0	17.8	7.00	24.7	Yes	3.82
6		170						1
7		170						0.17
8-8.56p	1.6	170	272.0	17.6	7.40	28.4	Yes	3.66
9		170						1.16
10-4.36p	2	170	340.0	20.9	7.10	21.3	Yes	0.83
11		170						3.82
12		170						1.16
13-7.16p	2	170	340.0	20.4	7.10	22.1	Yes	1.5
14		170						3.16
15-11.44a	1.8	170	306.0	14.8	7.00	30.2	Yes	2.83
16		170						0.83
17-9.48a	1.8	170	306.0	16.0	7.00	27.9	Yes	4.99
18-9.02a	1.8	170	306.0	15.2	7.00	29.4	Yes	4.82
19		170						2.66
20-3.22p	1.8	170	306.0	16.4	7.00	27.2	Yes	1.16
21		170						0.33
22		170						1.5
23		170						2.33
24-8.47a	1.8	170	306.0	14.4	7.00	31.1	Yes	2.83
25		170						1
26		170						2
27		170						0.83
28		170						0.83
29-4.48p	1.6	170	272.0	13.8	7.00	31.6	Yes	0.67
30		170						1.33
31		170						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013