

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **October 2025**

System Name:		Camp Tapawingo		ID#: 41		91259		WTP : TP -		A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]				
1						po					
2						po					
3						0.28					
4					0.24						
5					0.28						
6						po					
7						po					
8				0.28							
9						po					
10					0.47						
11						0.42					
12						po					
13					0.43						
14						po					
15					0.36						
16						po					
17					0.28						
18						0.22					
19					0.27						
20						po					
21						po					
22						po					
23					0.33						
24						po					
25					0.25						
26				0.60							
27						po					
28						po					
29					0.36						
30						po					
31						po					

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	SIGNATURE:	DATE:
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP - : A

System Name:	Camp Tapawingo	ID#: 41	91259	Month/Year: Oct-25	Disinfection <i>Giardia</i> Log	Inactiv:	1.0
---------------------	-----------------------	----------------	--------------	---------------------------	--	-----------------	------------

Date / Time	minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		170						0.54
2		170						0.91
3-8.02p	1.6	170	272.0	13.2	7.00	32.9	Yes	3.26
4-3.46p	2	170	340.0	16.3	7.00	28.0	Yes	3.81
5-4.51p	2	170	340.0	15.9	7.00	28.7	Yes	11.79
6		170						2.54
7		170						2
8-12.12p	2	170	340.0	16.1	7.00	28.4	Yes	1.45
9		170						1.09
10-3.37p	2.2	170	374.0	12.8	7.40	41.9	Yes	0.91
11-6.39p	1.8	170	306.0	14.3	7.30	34.9	Yes	3.26
12		170						1.81
13-4.15	2	170	340.0	13.4	6.90	32.7	Yes	2.54
14		170						2.54
15-3.19	1.6	170	272.0	11.5	6.90	36.2	Yes	3.99
16		170						3.26
17-4.24p	1.8	170	306.0	11.8	7.00	37.5	Yes	2.18
18-6.18p	2	170	340.0	12.0	7.00	37.9	Yes	4.9
19-4.49p	2	170	340.0	12.4	7.00	36.9	Yes	3.26
20		170						1.81
21		170						2.54
22		170						1.09
23-5.08p	1.8	170	306.0	11.8	7.00	37.5	Yes	1.63
24		170						1.63
25-4.22p	2	170	340.0	11.6	7.00	38.9	Yes	4.9
26-1.32p	2.2	170	374.0	12.6	6.90	35.3	Yes	7.8
27		170						1.27
28		170						0.91
29-4.22p	1.8	170	306.0	12.9	6.90	33.1	Yes	0.91
30		170						0.36
31		170						1.09

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013