

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **November 2025**

System Name:		Camp Tapawingo		ID#: 41		91259		WTP : TP -		A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]				
1						po					
2						po					
3						po					
4						po					
5				0.27							
6						po					
7						po					
8					0.60						
9						po					
10						po					
11						po					
12						po					
13						po					
14					0.51						
15					0.42						
16						po					
17						po					
18						po					
19						po					
20					0.36						
21						po					
22					0.41						
23					0.44						
24						po					
25						po					
26						po					
27						po					
28						po					
29				0.22							
30						po					
31						po					

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	SIGNATURE:	DATE:
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- : A
System Name: Camp Tapawingo ID#: 41 91259 Month/Year: Nov-25
Disinfection *Giardia* Log
Inactiv: 1.0

Date / Time	minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		170						3.33
2		170						2.99
3		170						7.81
4		170						1
5-1.58p	1.6	170	272.0	11.8	6.90	35.5	Yes	0.33
6		170						0.33
7		170						3.33
8-4.07p	2	170	340.0	15.0	7.20	32.9	Yes	4.49
9		170						4.16
10		170						2.83
11		170						1.66
12		170						1.66
13		170						1.66
14-3.47p	2	170	340.0	13.0	6.90	33.6	Yes	2.99
15-4.48p	2	170	340.0	13.5	6.90	32.5	Yes	2.33
16		170						2.33
17		170						1.16
18		170						0.83
19		170						1.16
20-2.20p	1.8	170	306.0	12.9	6.90	33.1	Yes	0.67
21		170						4.32
22-3.32p	1.8	170	306.0	9.6	6.80	40.4	Yes	6.65
23-4.16p	2	170	340.0	10.2	6.90	41.1	Yes	5.15
24		170						4.16
25		170						1.16
26		170						0.33
27		170						1
28		170						1.33
29-12.31	1.6	170	272.0	9.6	6.90	40.9	Yes	1
30		170						0.67
31		170						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013