

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **01/2026**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1						po	
2						po	
3						po	
4						po	
5					0.19		
6						po	
7						po	
8						po	
9					0.22		
10						po	
11						po	
12						po	
13						po	
14						po	
15						po	
16					0.16		
17						po	
18						po	
19				0.17			
20						po	
21						po	
22						po	
23						po	
24				0.26			
25						po	
26						po	
27						po	
28						po	
29						po	
30				0.38			
31						po	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>	<b>Yes</b>	<b>Yes</b>

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>SIGNATURE:</b>	<b>DATE:</b>
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

**WTP - : A**

**System Name: Camp Tapawingo**

**ID#: 41 91259**

**Month/Year: Jan-26**

**Disinfection *Giardia* Log Inactiv: 1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1		170						1
2		170						0.67
3		170						0.67
4		170						0.67
5-2.48p	2.2	170	374.0	10.1	6.70	39.5	Yes	1.83
6		170						1
7		170						0.83
8		170						1.16
9-2.12p	2	170	340.0	10.3	6.80	39.5	Yes	1
10		170						0.33
11		170						0.67
12		170						1.5
13		170						0.33
14		170						0.83
15		170						0.5
16-4.14p	2	170	340.0	9.0	6.60	40.1	Yes	2.49
17		170						6.32
18		170						5.49
19-11.16a	2	170	340.0	6.7	6.60	46.6	Yes	2.49
20		170						0.83
21		170						1.16
22		170						0.67
23		170						1.5
24-10.34a	2	170	340.0	6.0	6.60	48.9	Yes	1.33
25		170						1
26		170						1.16
27		170						0.33
28		170						0.67
29		170						0.5
30-12.02p	2	170	340.0	6.9	6.60	46.0	Yes	2.49
31		170						5.82

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013