

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **Feb 2026**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1						po	
2						po	
3						po	
4						po	
5						po	
6			0.23				
7						po	
8						po	
9						po	
10						po	
11			0.45				
12						po	
13						po	
14						po	
15						po	
16				0.20			
17						po	
18						po	
19						po	
20						po	
21						0.58	
22						po	
23						po	
24						po	
25					0.74		
26						po	
27						po	
28						po	
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>	<b>Yes</b>	<b>Yes</b>

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>SIGNATURE:</b>	<b>DATE:</b>
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: Feb-26

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		170						3.49
2		170						1.16
3		170						1.16
4		170						1.16
5		170						1.16
6-9.03a	1.8	170	306.0	7.4	6.70	45.1	Yes	0.83
7		170						0.33
8		170						0.67
9		170						1.16
10		170						1.16
11-9.39a	1.8	170	306.0	7.4	6.80	46.7	Yes	0.5
12		170						3.99
13		170						1
14		170						4.32
15		170						4.66
16-10.18a	2	170	340.0	8.3	6.60	42.0	Yes	2
17		170						1
18		170						3.82
19		170						3.16
20		170						3.33
21-6.54p	2.2	170	374.0	9.1	6.70	42.2	Yes	8.31
22		170						3.49
23		170						3.82
24		170						3.82
25-2.56p	2	170	340.0	10.2	6.80	39.7	Yes	3.49
26		170						2.99
27		170						0.5
28		170						1.16
29		170						
30		170						
31		170						

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.