

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **March 2026**

System Name: **Camp Tapawingo** **ID#: 41** **91259** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1						po	
2						po	
3					0.32		
4						po	
5						po	
6						po	
7					0.45		
8						po	
9						po	
10						po	
11						po	
12						po	
13						po	
14						po	
15						po	
16					0.29		
17						po	
18						po	
19					0.49		
20						po	
21						po	
22					0.27		
23						po	
24						po	
25						po	
26						po	
27						po	
28				0.37			
29						po	
30						po	
31						po	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? Yes	Yes	Yes

Notes:	PRINTED NAME: Brad Schmidt	
	SIGNATURE:	DATE:
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: Mar-26

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		170						0.33
2		170						0.83
3-4.28p	1.8	170	306.0	10.8	6.80	37.4	Yes	0.83
4		170						1
5		170						0.5
6		170						5.82
7-5.11p	1.8	170	306.0	11.2	6.70	35.2	Yes	1.16
8		170						0.17
9		170						1.66
10		170						2.99
11		170						0.83
12		170						1
13		170						1.83
14		170						0.33
15		170						1.16
16-5.37p	1.6	170	272.0	16.1	6.60	23.3	Yes	1.33
17		170						1
18		170						1
19-3.42	1.6	170	272.0	16.2	6.80	25.0	Yes	3.33
20		170						3.82
21		170						2.49
22-2.47	1.4	170	238.0	10.6	6.80	36.2	Yes	0.67
23		170						0.67
24		170						1.16
25		170						0.83
26		170						1.16
27		170						2.16
28-10.52a	1.4	170	238.0	12.8	6.80	30.7	Yes	1.33
29		170						1.16
30		170						1.16
31		170						1

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013