

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **2/2021**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							
2							
3							
4							
5			0.91				
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18			0.95				
19							
20							
21							
22							
23					0.89		
24							
25							
26							
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 2/2021

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						1.2
2		49						0.8
3		49						0.8
4		49						1.8
5/9.04am	2.6	49	127.4	7.6	8.40	90.4	Yes	1
6		49						0.3
7		49						1.2
8		49						1
9		49						1
10		49						1.2
11		49						0.8
12		49						0.8
13		49						0.7
14		49						1
15		49						1
16		49						0.3
17		49						0.5
18/9.58am	2.8	49	137.2	4.8	8.50	116.9	Yes	0.3
19		49						1
20		49						1.7
21		49						1
22		49						1
23/4.45pm	2.4	49	117.6	6.6	8.50	98.2	Yes	0.8
24		49						0.7
25		49						0.8
26		49						0.8
27		49						0.7
28		49						0.7
29		49						
30		49						
31		49						