

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **5/2021**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1							
2							
3							
4							
5				0.72			
6							
7							
8				0.89			
9							
10							
11							
12							
13			0.77				
14							
15							
16							
17							
18				0.96			
19				0.44			
20				0.39			
21							
22							
23							
24			0.44				
25				0.30			
26							
27				0.32			
28							
29							
30							
31					0.54		

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

**WTP- : A**

**System Name: Camp Tapawingo ID#: 41 91259 Month/Year: 5/2021**

**Disinfection *Giardia* Log Inactiv: 1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1		49						
2		49						
3		49						
4		49						
5/11.11am	3.2	49	156.8	121.4	8.30	-0.8	Yes	
6		49						
7		49						
8/10.03am	2.6	49	127.4	10.1	8.80	88.1	Yes	
9		49						
10		49						
11		49						
12		49						
13/9.40am	2.6	49	127.4	12.1	9.00	82.6	Yes	
14		49						
15		49						
16		49						
17		49						
18/11.25am	2.2	49	107.8	12.9	7.60	44.8	Yes	
19/12.02pm	2.6	49	127.4	11.9	8.20	62.5	Yes	
20/10.04am	2.6	49	127.4	10.7	8.00	63.1	Yes	
21		49						
22		49						
23		49						
14/9.56am	2.4	49	117.6	13.3	7.40	41.5	Yes	
25/10.19am	2.6	49	127.4	12.4	8.20	60.4	Yes	
26		49						
27/11.54am	2.4	49	117.6	12.5	8.10	56.5	Yes	
28		49						
29		49						
30		49						
31/3.42pm	2	49	98.0	17.4	8.20	40.5	Yes	