

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **6/2021**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1					0.41		
2				0.34			
3							
4							
5							
6							
7					0.44		
8							
9			0.41				
10							
11							
12							
13							
14			0.44				
15							
16							
17							
18					0.44		
19							
20							
21							
22						0.37	
23			0.50				
24			0.44				
25				0.53			
26							
27					0.36		
28			0.34				
29					0.43		
30					0.52		
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: **Camp Tapawingo** ID#: **41 91259** Month/Year: **6/2021** Disinfection *Giardia* Log Inactiv: **1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1/5.21pm	2.2	49	107.8	19.2	8.40	39.6	Yes	3
2/10.52am	2.4	49	117.6	18.0	8.50	45.5	Yes	5
3		49						5
4		49						4
5		49						3
6		49						5
7/4.36pm	2.8	49	137.2	14.1	8.40	59.4	Yes	3
8		49						8
9/9.45am	2.6	49	127.4	11.8	8.20	62.9	Yes	7
10		49						3
11		49						3
12		49						4
13		49						3
14/8.58am	3	49	147.0	13.7	8.00	53.9	Yes	4
15		49						6
16		49						4
17		49						6
18/2.15pm	2.8	49	137.2	16.4	8.10	45.7	Yes	6
19		49						3
20		49						3
21		49						5
22/6.27pm	2.6	49	127.4	17.8	7.80	36.5	Yes	11
23/9.26am	2.8	49	137.2	15.7	7.80	42.9	Yes	15.9
24/9.53am	2.8	49	137.2	16.0	7.80	42.0	Yes	12.9
25/1.46pm	2.6	49	127.4	18.2	7.80	35.5	Yes	11.9
26		49						4
27/4.42pm	2.8	49	137.2	20.8	7.80	30.5	Yes	5
28/9.42am	2	49	98.0	18.5	7.80	32.5	Yes	7
29/3.35pm	1.8	49	88.2	19.9	7.70	27.9	Yes	8
30/4.10pm	1.6	49	78.4	18.8	7.60	28.3	Yes	16.9
31		49						