

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **9/2021**

System Name: <b>Camp Tapawingo</b>		ID#: <b>41 91259</b>		WTP : <b>TP - A</b>			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1			0.28				
2				0.24			
3			0.24				
4			0.23				
5			0.23				
6				0.28			
7			0.24				
8			0.27				
9			0.28				
10			0.30				
11				0.26			
12				0.24			
13			0.21				
14					0.33		
15					0.27		
16			0.29				
17				0.27			
18							
19							
20				0.46			
21							
22				0.41			
23			0.35				
24			0.28				
25				0.39			
26				0.26			
27							
28							
29							
30				0.40			
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	<b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>
<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>		
	<b>PHONE #: ( 503 ) 787-3828</b>		<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

**WTP- : A**

**System Name: Camp Tapawingo**

**ID#: 41 91259**

**Month/Year: 9/2021**

**Disinfection *Giardia* Log Inactiv: 1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1/8.07am	1.8	49	88.2	13.6	8.00	47.4	Yes	1.5
2/1.50pm	1.8	49	88.2	17.1	8.00	37.6	Yes	1.2
3/8.33am	1.9	49	93.1	13.8	7.90	45.6	Yes	5.5
4/10.42am	1.7	49	83.3	15.1	7.90	40.9	Yes	0.7
5/11.30am	1.7	49	83.3	16.6	7.90	37.0	Yes	0.8
6/2.37pm	1.8	49	88.2	18.4	8.00	34.4	Yes	1.7
7/11.23am	1.9	49	93.1	15.8	7.00	28.6	Yes	5.2
8/10.19am	1.8	49	88.2	16.3	8.00	39.6	Yes	5.2
9/11.11am	1.7	49	83.3	18.0	8.00	35.0	Yes	4.2
10/8.39am	1.7	49	83.3	16.2	8.20	42.4	Yes	6.3
11/1.21pm	1.8	49	88.2	16.9	8.00	38.1	Yes	0.8
12/2.59pm	1.8	49	88.2	16.8	8.00	38.3	Yes	1.3
13/8.30am	1.8	49	88.2	14.2	8.00	45.5	Yes	3.2
14/4.04pm	1.8	49	88.2	18.5	8.00	34.2	Yes	0.7
15/6.31pm	1.9	49	93.1	17.4	8.00	37.2	Yes	1
16/8.17am	1.9	49	93.1	13.1	7.90	47.7	Yes	7.6
17/2.48pm	1.8	49	88.2	16.6	8.00	38.8	Yes	3.3
18		49						3.7
19		49						12.3
20/2.23pm	1.5	49	73.5	17.1	8.10	37.7	Yes	12
21		49						1.5
22/1.13pm	1.7	49	83.3	16.9	8.00	37.6	Yes	4.3
23/8.00am	1.8	49	88.2	14.0	8.00	46.1	Yes	6.5
24/8.30am	2	49	98.0	13.6	8.00	48.4	Yes	4.8
25/3.23pm	1.9	49	93.1	16.9	8.00	38.5	Yes	1.2
26/12.27pm	1.8	49	88.2	15.2	7.90	41.1	Yes	1.3
27		49						0.5
28		49						0.8
29		49						1.2
30/3.23pm	1.5	49	73.5	16.3	8.00	38.3	Yes	0.7
31		49						