

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **12/2021**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							
2							
3							
4							
5							
6			0.47				
7			0.71				
8							
9							
10			0.68				
11							
12							
13			0.67				
14							
15							
16			0.89				
17							
18							
19							
20			0.55				
21			0.77				
22							
23			0.86				
24				0.68			
25							
26							
27							
28							
29							
30			0.60				
31			0.37				

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
Notes:	PRINTED NAME: Brad Schmidt		
	PHONE #: (503) 787-3828		CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 12/2021

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						1
2		49						1.5
3		49						1
4		49						0.7
5		49						1.3
6/8.25am	2.2	49	107.8	8.7	8.20	74.2	Yes	1.8
7/8.42am	2.2	49	107.8	10.2	8.30	69.5	Yes	1.8
8		49						1.5
9		49						2
10/8.27am	1.9	49	93.1	7.7	8.30	79.6	Yes	2
11		49						1.7
12		49						1.7
13/8.25am	1.7	49	83.3	7.3	8.30	80.0	Yes	1.5
14		49						1.8
15		49						2.5
16/8.23am	1.6	49	78.4	7.5	8.30	77.9	Yes	1.7
17		49						1.8
18		49						1.7
19		49						1.8
20/8.39am	1.7	49	83.3	7.3	8.40	83.0	Yes	2.5
21/8.41am	2.2	49	107.8	8.2	8.40	82.7	Yes	2.2
22		49						2
23/9.34am	2.2	49	107.8	7.6	8.40	86.2	Yes	1.8
24/3.24pm	2.2	49	107.8	7.4	8.40	87.4	Yes	2.5
25		49						1.8
26		49						2.2
27		49						1.7
28		49						1.8
29		49						1.7
30/8.52am	2.2	49	107.8	6.1	8.40	95.7	Yes	2.3
31/8.35am	2.3	49	112.7	7.1	8.50	93.8	Yes	2.2