

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **1/2022**

System Name: **Camp Tapawingo** ID#: **41 91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							
2							
3							
4				0.64			
5							
6							
7				0.62			
8			0.51				
9							
10							
11				0.51			
12					0.34		
13							
14			0.44				
15							
16							
17			0.50				
18			0.36				
19							
20							
21				0.36			
22							
23							
24			0.45				
25				0.38			
26							
27							
28			0.38				
29					0.34		
30							
31			0.40				

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 1/2022

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						
2		49						
3		49						
4/1.22pm	2.5	49	122.5	6.5	8.50	100.1	Yes	
5		49						
6		49						
7/12.57pm	2.5	49	122.5	7.4	8.50	94.0	Yes	
8/10.05am	2.2	49	107.8	7.1	8.50	92.6	Yes	
9		49						
10		49						
11/3.12pm	2	49	98.0	9.1	8.50	78.7	Yes	
12/4.37pm	2	49	98.0	8.9	8.50	79.8	Yes	
13		49						
14/8.45am	2.3	49	112.7	7.2	8.50	93.1	Yes	
15		49						
16		49						
17/10.42am	2.1	49	102.9	6.6	8.50	94.8	Yes	
18/10.45am	2.3	49	112.7	7.2	8.60	96.6	Yes	
19		49						
20		49						
21/12.00pm	2.1	49	102.9	8.8	8.60	84.4	Yes	
22		49						
23		49						
24/8.50am	2.1	49	102.9	6.2	8.60	101.2	Yes	
24/2.20pm	2	49	98.0	7.7	8.50	86.8	Yes	
26		49						
27		49						
28/8.39am	2.2	49	107.8	5.3	8.70	113.2	No	
29/6.38pm	2.3	49	112.7	7.8	8.70	96.2	Yes	
30		49						
31/9.10am	2.2	49	107.8	6.2	8.80	110.3	No	