

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **2/2022**

System Name: **Camp Tapawingo** **ID#: 41** **91259** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.45				
2							
3							
4			0.41				
5			0.43				
6							
7							
8			0.62				
9			0.52				
10			0.44				
11			0.28				
12				0.35			
13							
14							
15				0.39			
16					0.35		
17							
18			0.36				
19			0.35				
20			0.44				
21		0.46					
22							
23							
24				0.38			
25				0.32			
26				0.33			
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
Notes:	PRINTED NAME: Brad Schmidt		
	PHONE #: (503) 787-3828		CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 2/2022

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/8.35am	2.2	49	107.8	7.5	8.00	74.9	Yes	2.5
2		49						2.8
3		49						2.2
4/11.30am	2.1	49	102.9	6.2	8.00	81.0	Yes	1.8
5/11.21am	2.1	49	102.9	8.8	8.00	67.7	Yes	1.7
6		49						2.3
7		49						1.8
8/8.53am	2.2	49	107.8	6.2	8.00	82.0	Yes	2.3
9/8.17am	2.1	49	102.9	8.2	8.00	70.6	Yes	3
10/11.28am	2	49	98.0	8.8	8.10	69.4	Yes	2.2
11/9.32am	2.4	49	117.6	7.5	8.00	76.7	Yes	2.3
12/2.30pm	2.5	49	122.5	9.3	8.10	71.1	Yes	3.2
13		49						2.2
14		49						1.8
15/8.29am	2.4	49	117.6	7.2	8.10	81.3	Yes	3.5
16/4.25pm	2.4	49	117.6	9.3	8.00	67.8	Yes	2.5
17		49						1.8
18/8.52am	2.4	49	117.6	7.4	8.10	80.1	Yes	2.7
19/8.58am	2.4	49	117.6	7.3	8.10	80.7	Yes	5
20/10.53am	2.4	49	117.6	8.2	8.10	75.8	Yes	6
21/7.54am	2.3	49	112.7	6.9	8.10	82.0	Yes	4
22		49						2.2
23		49						2.2
24/3.20pm	2.4	49	117.6	7.6	8.20	82.0	Yes	2.2
25/3.40pm	2.4	49	117.6	7.5	8.20	82.6	Yes	2.3
26/1.28pm	2.4	49	117.6	6.3	8.20	89.7	Yes	3
27		49						2.2
28		49						3.5
29		49						
30		49						
31		49						