

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **3/2022**

System Name: **Camp Tapawingo** **ID#: 41** **91259** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					0.71		
2						PO	
3						PO	
4						PO	
5				0.83			
6						PO	
7						PO	
8						PO	
9			0.94				
10						PO	
11			0.36				
12			0.33				
13						PO	
14				0.41			
15				0.69			
16					0.51		
17			0.41				
18						PO	
19			0.55				
20						PO	
21						PO	
22			0.40				
23				0.35			
24				0.30			
25			0.31				
26				0.59			
27						PO	
28						PO	
29					0.46		
30			0.34				
31						PO	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 3/2022

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/1.08PM	2.4	49	117.6	11.8	9.00	82.4	Yes	3
2		49						2.8
3		49						2
4		49						2.2
5/11.50AM	2.2	49	107.8	9.4	7.80	61.2	Yes	2.2
6		49						1.8
7		49						2.2
8		49						3
9/10.33AM	2.2	49	107.8	8.8	7.80	63.7	Yes	2.2
10		49						2.8
11/10.32AM	2	49	98.0	8.4	7.10	49.7	Yes	4.1
12/8.33AM	2.1	49	102.9	6.9	7.50	64.3	Yes	5.3
13		49						4.1
14/3.31PM	2.1	49	102.9	9.0	7.60	57.8	Yes	4.1
15/3.40PM	2	49	98.0	9.2	7.80	60.6	Yes	6.5
16/4.43PM	2	49	98.0	10.1	7.70	55.0	Yes	14.3
17/11.37AM	2	49	98.0	8.1	7.80	65.3	Yes	14.6
18		49						13.8
19/11.04AM	2	49	98.0	9.1	7.80	61.0	Yes	3.2
20		49						2
21		49						2.7
22/9.15AM	1.9	49	93.1	8.9	7.90	63.4	Yes	2.3
23/1.30PM	2	49	98.0	10.2	7.80	56.6	Yes	2.3
24/3.10PM	1.7	49	83.3	10.5	7.80	53.6	Yes	3
25/12.12PM	2.1	49	102.9	9.9	8.00	62.8	Yes	4.3
26/12.15PM	2.5	49	122.5	10.3	7.90	61.8	Yes	3.8
27		49						2.2
28		49						2.8
29/5.45PM	2.5	49	122.5	11.7	8.00	58.2	Yes	2.7
30/8.29AM	2.5	49	122.5	10.2	8.00	64.5	Yes	2.3
31		49						2.7