

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **4/2022**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					0.48		
2				0.82			
3				0.37			
4							
5							
6					0.94		
7				0.46			
8			0.30				
9			0.30				
10					0.29		
11							
12				0.35			
13				0.45			
14							
15							
16				0.32			
17							
18					0.43		
19			0.51				
20					0.44		
21				0.53			
22							
23							
24							
25							
26			0.48				
27			0.33				
28				0.39			
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 4/2022

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/3.03pm	2.6	49	127.4	12.0	8.00	57.7	Yes	3.5
2/10.51am	3	49	147.0	9.5	8.00	71.7	Yes	10.3
3/10.23am	3	49	147.0	10.0	8.00	69.3	Yes	4.3
4		49			po			2.5
5		49			po			3.2
6/4.12pm	2.6	49	127.4	11.1	8.00	61.4	Yes	2.3
7/3.51pm	2.6	49	127.4	13.6	8.00	51.8	Yes	2.3
8/8.28am	2.5	49	122.5	9.7	7.90	64.4	Yes	5
9/9.3am	2.5	49	122.5	8.4	8.00	73.0	Yes	5.7
10/4.46pm	1.8	49	88.2	8.9	7.90	62.6	Yes	5.3
11		49			po			3
12/2.24pm	2.6	49	127.4	7.9	7.90	73.7	Yes	3.3
13/2.07pm	2.4	49	117.6	8.8	8.00	70.1	Yes	2.3
14		49			po			2.8
15		49			po			2.5
16/10.45am	2.5	49	122.5	9.1	7.80	64.6	Yes	2.5
17		49			po			2.3
18/2.32pm	2.5	49	122.5	8.6	7.90	69.4	Yes	2.2
19/8.49am	2.8	49	137.2	8.8	8.00	73.5	Yes	2.2
20/6.09pm	2.7	49	132.3	10.1	8.10	68.9	Yes	2.2
21/11.53am	2.6	49	127.4	9.5	8.10	71.0	Yes	2.8
22		49			po			0.8
23		49			po			0.8
24		49			po			1
25		49			po			2
26/8.31am	2.1	49	102.9	8.9	8.10	69.8	Yes	2.5
27/9.40am	2.4	49	117.6	9.5	8.10	69.4	Yes	4.8
28/2.17pm	2	49	98.0	10.3	7.90	58.3	Yes	3
29		49			po			1.3
30		49			po			1
31		49						