

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **5/2022**

System Name: **Camp Tapawingo** ID#: **41 91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							
2							
3			0.37				
4				0.46			
5							
6							
7							
8							
9							
10							
11			0.39				
12				0.32			
13			0.42				
14							
15							
16							
17			0.46				
18							
19							
20							
21							
22							
23			0.53				
24					0.34		
25					0.36		
26							
27							
28			0.35				
29					0.40		
30				0.38			
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 5/2022

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49			po			0.7
2		49			po			0.3
3/8.07am	2	49	98.0	9.8	8.10	64.8	Yes	1.2
4/1.27pm	2	49	98.0	12.2	8.70	68.5	Yes	1
5		49			po			1
6		49			po			1.2
7		49			po			1.2
8		49			po			1.5
9		49			po			0.5
10		49			po			0.5
11/8.02am	1.9	49	93.1	8.4	8.40	78.7	Yes	2.3
12/12.37pm	2.3	49	112.7	10.0	8.00	63.9	Yes	2.7
13/10.26am	2.3	49	112.7	9.0	8.00	68.4	Yes	2.8
14		49			po			1.5
15		49			po			1.2
16		49			po			1.2
17/8.48am	2	49	98.0	10.3	8.70	78.0	Yes	0.8
18		49			po			1.3
19		49			po			1.5
20		49			po			1.2
21		49			po			1.8
22		49			po			13.8
23/9.24am	2.4	49	117.6	12.1	7.90	54.1	Yes	0.8
24/4.37pm	2.2	49	107.8	13.3	8.00	50.5	Yes	2.5
25/4.53pm	2.2	49	107.8	14.9	8.00	45.5	Yes	10.5
26		49			po			3
27		49			po			3
28/8.49am	2.1	49	102.9	11.8	8.10	57.3	Yes	3.8
29/5.39pm	2.3	49	112.7	12.6	7.90	51.6	Yes	5.3
30/1.21pm	2.4	49	117.6	12.3	8.00	55.3	Yes	2.3
31		49						