

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **7-2022**

System Name: **Camp Tapawingo** ID#: **41 91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1				0.66			
2							
3							
4			0.43				
5					.47.5		
6							
7			0.50				
8				0.38			
9							
10			0.35				
11			0.30				
12							
13				0.38			
14							
15				0.37			
16							
17							
18			0.44				
19			0.32				
20					0.30		
21							
22					0.39		
23							
24							
25							
26				0.33			
27				0.32			
28				0.36			
29				0.39			
30					0.38		
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: **Camp Tapawingo**

ID#: **41 91259**

Month/Year: **7-2022**

Disinfection *Giardia* Log
Inactiv: **1.0**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/10.33am	1.8	49	88.2	16.1	8.10	41.6	Yes	
2		49						
3		49						
4/9.20am	1.8	49	88.2	14.5	8.10	46.3	Yes	
5/2.34pm	2	49	98.0	15.6	8.10	44.0	Yes	
6		49						
7/7.37am	2.2	49	107.8	14.7	8.10	47.8	Yes	
8/11.11am	1.8	49	88.2	14.8	8.10	45.4	Yes	
9		49						
10/9.33am	1.8	49	88.2	13.8	8.10	48.5	Yes	
11/9.32am	2	49	98.0	15.5	8.20	46.0	Yes	
12		49						
13/11.03am	1.8	49	88.2	15.8	8.20	44.1	Yes	
14		49						
15/10.31am	1.8	49	88.2	16.1	8.20	43.2	Yes	
16		49						
17		49						
18/9.50am	1.6	49	78.4	15.1	8.10	43.5	Yes	
19/7.47am	1.6	49	78.4	14.6	8.20	46.6	Yes	
20/4.16am	2	49	98.0	18.5	8.20	37.7	Yes	
21		49						
22/2.28pm	1.8	49	88.2	17.7	8.20	38.9	Yes	
23		49						
24		49						
25		49						
26/12.10pm	1.6	49	78.4	18.0	8.20	37.2	Yes	
27/11.39am	1.8	49	88.2	18.1	8.20	37.8	Yes	
28/1.20pm	2	49	98.0	19.7	8.10	33.5	Yes	
29/10.56am	2	49	98.0	19.0	8.20	36.5	Yes	
30/4.46pm	1.6	49	78.4	19.8	8.20	33.0	Yes	
31		49						