

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **9/2022**

System Name: **Camp Tapawingo** **ID#: 41** **91259** **WTP : TP -** **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1				0.43			
2				0.36			
3				0.40			
4				0.36			
5			0.31				
6						po	
7					0.54		
8					0.34		
9						po	
10					0.24		
11						po	
12				0.24			
13					0.23		
14				0.34			
15						po	
16					0.21		
17				0.42			
18			0.26				
19			0.22				
20						po	
21				0.35			
22				0.36			
23			0.34				
24			0.48				
25			0.35				
26						po	
27						po	
28						po	
29						po	
30						po	
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 9/2022

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/10.27am	1	49	49.0	16.8	7.40	28.0	Yes	6.2
2/1.23pm	1.2	49	58.8	19.3	7.50	25.2	Yes	10.3
3/11.01am	2	49	98.0	17.1	7.70	34.4	Yes	7.8
4/10.20am	2.6	49	127.4	17.1	7.80	38.2	Yes	7.5
5/9.45am	2.6	49	127.4	16.9	7.50	34.7	Yes	9.6
6		49						7.6
7/3.44pm	2.4	49	117.6	20.3	7.50	27.0	Yes	8.5
8/3.11pm	2.2	49	107.8	17.8	7.80	34.8	Yes	8
9		49						1.7
10/4.11pm	1.8	49	88.2	18.9	7.60	28.7	Yes	1
11		49						0.5
12/11.34am	2	49	98.0	16.4	7.70	36.0	Yes	7.3
13/3.55pm	2.2	49	107.8	18.6	7.80	33.0	Yes	1.5
14/10.31am	2	49	98.0	16.5	7.80	37.1	Yes	1.8
15		49						1.2
16/5.16pm	2.2	49	107.8	16.8	7.70	35.9	Yes	2.3
17/10.27am	2	49	98.0	14.6	7.70	40.6	Yes	1.7
18/9.10am	1.8	49	88.2	14.1	7.70	41.0	Yes	2.8
19/9.05am	2	49	98.0	13.6	7.60	41.8	Yes	5.3
20		49						0.8
21/12.02pm	2.2	49	107.8	15.3	7.70	39.7	Yes	4.3
22/11.42am	1.8	49	88.2	14.7	7.60	38.0	Yes	4.7
23/8.46am	1.8	49	88.2	13.0	7.60	42.5	Yes	5.5
24/8.26am	1.8	49	88.2	12.7	7.60	43.4	Yes	2.3
25/8.51am	1.8	49	88.2	12.9	7.60	42.8	Yes	0.2
26		49						6.6
27		49						1.3
28		49						0.8
29		49						1.7
30		49						0.5
31		49						