

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **10/2022**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1						PO	
2						PO	
3			0.56				
4					0.29		
5				0.45			
6						PO	
7				0.46			
8			0.27				
9					0.42		
10						PO	
11						PO	
12						PO	
13					0.38		
14			0.55				
15			0.78				
16					0.34		
17						PO	
18						PO	
19					0.57		
20						PO	
21					0.49		
22						PO	
23					0.42		
24						PO	
25						PO	
26						PO	
27					0.38		
28						PO	
29						PO	
30						PO	
31						PO	

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 10/2022

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49						0.7
2		49						1.2
3/9.20AM	2	49	98.0	14.1	7.90	45.2	Yes	0.8
4/2.25PM	2	49	98.0	16.9	8.00	38.9	Yes	0.7
5/10.00AM	1.6	49	78.4	13.4	7.30	36.3	Yes	2
6		49						4.8
7/10.52AM	2	49	98.0	13.8	7.20	35.6	Yes	3.6
8/8.09AM	2	49	98.0	13.1	7.30	38.7	Yes	5.2
9/5.44PM	2	49	98.0	15.6	7.30	32.8	Yes	4
10		49						5
11		49						0.3
12		49						1.2
13/3.11PM	2	49	98.0	15.0	7.20	32.9	Yes	6
14/9.27AM	1.4	49	68.6	12.3	7.20	37.2	Yes	1.8
15/9.17AM	1.8	49	88.2	12.3	7.40	41.7	Yes	2.7
16/5.38PM	1.8	49	88.2	14.5	7.20	33.2	Yes	2.2
17		49						0.8
18		49						5.7
19/2.06PM	1.8	49	88.2	13.7	7.40	37.7	Yes	0.5
20		49						0.3
21/5.56PM	2.2	49	107.8	12.0	7.20	41.5	Yes	1.7
22		49						2.7
23/3.51PM	2	49	98.0	12.2	7.30	41.5	Yes	3.3
24		49						0.3
25		49						0.8
26		49						0.8
27/5.09PM	1.6	49	78.4	11.2	7.30	42.4	Yes	1
28		49						1.3
29		49						2.5
30		49						2.7
31		49						1