

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **11/2022**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1					PO		
2					0.57		
3					0.42		
4					PO		
5					PO		
6					PO		
7					PO		
8					0.70		
9					PO		
10					PO		
11					PO		
12					PO		
13					PO		
14					PO		
15					PO		
16					PO		
17					0.50		
18					PO		
19					PO		
20					PO		
21					PO		
22					PO		
23					0.34		
24					PO		
25					PO		
26					PO		
27					PO		
28					PO		
29					PO		
30					PO		
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>	<b>Yes</b>	<b>Yes</b>

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo

ID#: 41 91259

Month/Year: 11/2022

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1		49						1
2/4.42pm	1.6	49	78.4	11.4	7.50	44.8	Yes	2
3/4.39pm	1.6	49	78.4	8.7	7.30	50.0	Yes	1.2
4		49						0.5
5		49						1.2
6		49						1
7		49						1.5
8/3.38pm	1.8	49	88.2	7.6	7.20	53.1	Yes	2
9		49						1
10		49						0.5
11		49						0.8
12		49						1.8
13		49						2.3
14		49						1.3
15		49						1.2
16		49						1.2
17/4.25pm	1.8	49	88.2	7.2	7.50	60.8	Yes	0.7
18		49						3
19		49						3.6
20		49						2.8
21		49						2.2
22		49						0.8
23/3.34pm	1.4	49	68.6	7.5	7.50	56.9	Yes	0.8
24		49						0.8
25		49						2
26		49						0.7
27		49						0.7
28		49						1.2
29		49						2.3
30		49						3.6
31		49						