

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **12/2022**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1							
2							
3					0.52		
4							
5			0.63				
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18					0.37		
19				0.46			
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		

Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : A

System Name: Camp Tapawingo ID#: 41 91259 Month/Year: 12/2022

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		49			PO			1
2		49			PO			1.5
3/3.33pm	1.6	49	78.4	7.1	7.50	59.8	Yes	4.5
4		49			PO			5.2
5/9.13am	1.8	49	88.2	6.5	7.50	63.8	Yes	5.3
6		49			PO			3.5
7		49			PO			PO Maint.
8		49			PO			PO Maint.
9		49			PO			0.8
10		49			PO			2.2
11		49			PO			2.5
12		49			PO			2.3
13		49			PO			2.2
14		49			PO			1.2
15		49			PO			1.3
16		49			PO			0.5
17		49			PO			1.2
18/3.24pm	1.8	49	88.2	8.5	7.40	53.7	Yes	0.7
19/11.28am	1.6	49	78.4	6.9	7.40	58.5	Yes	2.2
20		49			PO			1.5
21		49			PO			1.3
22		49			PO			1.3
23		49			PO			0.8
24		49			PO			0.8
25		49			PO			0.5
26		49			PO			1
27		49			PO			PO Maint.
28		49			PO			PO Maint.
29		49			PO			PO Maint.
30		49			PO			PO Maint.
31		49			PO			PO Maint.