

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Polk**  
 Month/Year: **1/2023**

System Name: **Camp Tapawingo** ID#: **41 91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1							
2							
3							
4							
5							
6				0.82			
7							
8							
9							
10					0.74		
11							
12							
13							
14							
15							
16					0.98		
17				0.56			
18							
19							
20				0.48			
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <b>Yes</b>	CT's met everyday? (see back) <b>Yes</b>	All Cl2 residual at entry point ≥ 0.2 mg/l? <b>Yes</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes</b>		

<b>Notes:</b>	<b>PRINTED NAME: Brad Schmidt</b>	
	<b>PHONE #: ( 503 ) 787-3828</b>	<b>CERT #: N/A</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

**WTP - : A**

**System Name: Camp Tapawingo ID#: 41 91259 Month/Year: Jan-23**

**Disinfection *Giardia* Log Inactiv: 1.0**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1		49			PO			off maint.
2		49			PO			off maint.
3		49			PO			1.7
4		49			PO			0.8
5		49			PO			2.7
6/10.49am	2.2	49	107.8	8.5	7.50	58.3	Yes	0.5
7		49			PO			1.5
8		49			PO			0.3
9		49			PO			3.7
10/5.00pm	2	49	98.0	7.4	7.50	61.4	Yes	3.7
11		49			PO			1.3
12		49			PO			4.2
13		49			PO			2.5
14		49			PO			4.7
15		49			PO			3.8
16/4.25pm	2	49	98.0	7.8	7.50	59.8	Yes	1.2
17/11.12am	2	49	98.0	7.6	7.50	60.6	Yes	1.5
18		49			PO			1.2
19		49			PO			0.8
20/11.38am	2	49	98.0	7.7	7.50	60.2	Yes	2.7
21		49			PO			0.5
22		49			PO			0.7
23		49			PO			2.7
24		49			PO			2.3
25		49			PO			2
26		49			PO			0.7
27		49			PO			0.7
28		49			PO			0.8
29		49			PO			0.3
30		49			PO			1
31		49			PO			1.3