

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Polk**
 Month/Year: **2/2023**

System Name: **Camp Tapawingo** ID#: **41** **91259** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1					0.48		
2				PO			
3				PO			
4			0.60				
5				PO			
6				PO			
7				PO			
8				PO			
9				PO			
10				PO			
11				PO			
12			0.86				
13				PO			
14					0.48		
15				PO			
16				PO			
17				PO			
18				PO			
19				PO			
20				PO			
21				0.56			
22				PO			
23				PO			
24				PO			
25				0.60			
26				PO			
27				PO			
28				PO			
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		
Notes:	PRINTED NAME: Brad Schmidt	
	PHONE #: (503) 787-3828	CERT #: N/A

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : A

System Name: Camp Tapawingo ID#: 41 91259 Month/Year: 2/2023

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/2.56pm	1.6	49	78.4	6.2	7.50	63.6	Yes	0.7
2		49						0.8
3		49						1.2
4/9.03am	2	49	98.0	7.0	7.60	65.4	Yes	2.3
5		49						0.7
6		49						0.8
7		49						0.7
8		49						1.5
9		49						0.3
10		49						0.7
11		49						1
12/7.50am	1.8	49	88.2	6.0	7.50	66.0	Yes	1.2
13		49						1.2
14/3.26pm	1.8	49	88.2	7.2	7.50	60.8	Yes	1
15		49						1
16		49						0.8
17		49						1.3
18		49						3.8
19		49						3.8
20		49						2.5
21/10.28am	1.6	49	78.4	6.9	7.50	60.6	Yes	1.3
22		49						0.8
23		49						1
24		49						OFF maint.
25/11.06am	1.4	49	68.6	7.5	7.50	56.9	Yes	4
26		49						2.2
27		49						2.2
28		49						1.5
29		49						
30		49						
31		49						