


OHA - Drinking Water Services - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Jackson  
 Month/Year: 23-Nov

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.19	0.17	0.18	0.20	0.18	0.19	0.20
2	0.17	0.18	0.16	0.20	0.19	0.18	0.20
3	0.18	0.19	0.18	0.17	0.22	0.21	0.22
4	0.19	0.17	0.15	0.17	0.14	0.15	0.19
5	0.20	0.20	0.22	0.15	0.20	0.19	0.22
6	0.18	0.18	0.16	0.20	0.19	0.18	0.20
7	0.18	0.16	0.17	0.15	0.21	0.20	0.21
8	0.17	0.17	0.15	0.18	0.17	0.19	0.19
9	0.19	0.18	0.15	0.16	0.14	0.17	0.19
10	0.17	0.16	0.14	0.18	0.16	0.18	0.18
11	0.16	0.14	0.11	0.13	0.15	0.14	0.16
12	0.14	0.15	0.17	0.15	0.15	0.16	0.17
13	0.13	0.16	0.13	0.14	0.17	0.18	0.18
14	0.15	0.17	0.15	0.16	0.18	0.17	0.18
15	0.17	0.18	0.18	0.18	0.20	0.19	0.20
16	0.16	0.17	0.15	0.20	0.17	0.19	0.20
17	0.18	0.19	0.18	0.21	0.17	0.16	0.21
18	0.17	0.17	0.15	0.16	0.16	0.16	0.17
19	0.14	0.18	0.15	0.11	0.17	0.18	0.18
20	0.13	0.16	0.15	0.14	0.19	0.19	0.19
21	0.14	0.13	0.11	0.18	0.23	0.18	0.23
22	0.15	0.18	0.21	0.22	0.19	0.17	0.22
23	0.18	0.19	0.22	0.20	0.19	0.19	0.22
24	0.19	0.18	0.20	0.20	0.19	0.19	0.20
25	0.20	0.21	0.23	0.21	0.17	0.17	0.23
26	0.19	0.16	0.11	0.13	0.18	0.18	0.19
27	0.15	0.14	0.13	0.16	0.19	0.18	0.19
28	0.14	0.15	0.13	0.17	0.21	0.19	0.21
29	0.19	0.17	0.15	0.20	0.18	0.17	0.20
30	0.17	0.18	0.19	0.16	0.16	0.18	0.19
31	0.15	0.19	0.17	0.17	0.19	0.18	0.19

95% ↓ All ↓ 5	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<b>Monthly Summary (Answer Yes or No)</b>	
	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Mark Cleaner		SIGNATURE: 	
		5303834088	CERT #: 12/10/2023

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: -

System Name: Callahan's

ID#: 41 91551

Month/Year: NOV/23

Disinfection Giardia Log

Inactiv: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.1	25.2	52.9	9.7	7.39	51.1	YES	
2	2.13	25.2	53.7	10.3	7.40	49.5	YES	
3	2.05	25.2	51.7	10.3	7.50	50.8	YES	
4	2.12	25.2	53.4	10.4	7.45	50.0	YES	
5	2.03	25.2	51.2	10.4	7.44	49.3	YES	
6	2.1	25.2	52.9	10.6	7.62	52.3	YES	
7	2.05	25.2	51.7	10.7	7.45	48.6	YES	
8	2.03	25.2	51.2	10.2	7.30	47.5	YES	
9	2	25.2	50.4	10.5	7.46	49.1	YES	
10	2.18	25.2	54.9	9.1	7.45	54.9	YES	
11	2.16	25.2	54.4	9.6	7.42	52.4	YES	
12	2.18	25.2	54.9	9.6	7.41	52.3	YES	
13	2.2	25.2	55.4	9.6	7.42	52.6	YES	
14	2.25	25.2	56.7	9.6	7.51	54.7	YES	
15	2.1	25.2	52.9	10.2	7.46	50.7	YES	
16	2.2	25.2	55.4	9.8	7.45	52.5	YES	
17	2	25.2	50.4	10.3	7.39	48.6	YES	
18	2.16	25.2	54.4	9.5	7.49	54.1	YES	
19	2.17	25.2	54.7	9.1	7.44	54.6	YES	
20	2.1	25.2	52.9	9.7	7.41	51.5	YES	
21	2.16	25.2	54.4	9.9	7.49	52.6	YES	
22	2.19	25.2	55.2	10.0	7.46	51.9	YES	
23	2.2	25.2	55.4	9.3	7.50	55.3	YES	
24	2.2	25.2	55.4	9.7	7.49	53.6	YES	
25	2.3	25.2	58.0	8.9	7.45	56.4	YES	
26	2.5	25.2	63.0	8.7	7.50	59.6	YES	
27	2.42	25.2	61.0	8.1	7.47	60.8	YES	
28	2.41	25.2	60.7	8.0	7.45	60.7	YES	
29	2.52	25.2	63.5	7.6	7.45	63.2	YES	
30	2.61	25.2	65.8	7.3	7.44	65.0	YES	
31	2.65	25.2	66.8	7.2	7.45	65.9	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp\_dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350