

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Jackson

Cartridge or Bag Filtration

Month/Year: 25-Dec

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	6.00	12.00	-6.00	30.00	0.15	0.15
2	6.00	12.00	-6.00	30.00	0.15	0.15
3	6.00	12.00	-6.00	30.00	0.16	0.16
4	6.00	12.00	-6.00	30.00	0.15	0.15
5	6.00	12.00	-6.00	30.00	0.17	0.17
6	6.00	12.00	-6.00	30.00	0.15	0.15
7	6.00	12.00	-6.00	30.00	0.16	0.16
8	6.00	12.00	-6.00	30.00	0.18	0.18
9	6.00	12.00	-6.00	30.00	0.17	0.17
10	6.00	12.00	-6.00	30.00	0.16	0.16
11	6.00	12.00	-6.00	30.00	0.17	0.17
12	6.00	12.00	-6.00	30.00	0.16	0.16
13	6.00	12.00	-6.00	30.00	0.16	0.16
14	6.00	12.00	-6.00	30.00	0.17	0.17
15	6.00	12.00	-6.00	30.00	0.16	0.16
16	6.00	12.00	-6.00	30.00	0.15	0.15
17	6.00	12.00	-6.00	30.00	0.16	0.16
18	6.00	12.00	-6.00	30.00	0.17	0.17
19	6.00	12.00	-6.00	30.00	0.17	0.17
20	6.00	12.00	-6.00	30.00	0.16	0.16
21	6.00	12.00	-6.00	30.00	0.15	0.15
22	6.00	12.00	-6.00	30.00	0.16	0.16
23	6.00	12.00	-6.00	30.00	0.16	0.16
24	6.00	12.00	-6.00	30.00	0.17	0.17
25	6.00	12.00	-6.00	30.00	0.16	0.16
26	6.00	12.00	-6.00	30.00	0.15	0.15
27	6.00	12.00	-6.00	30.00	0.15	0.15
28	6.00	12.00	-6.00	30.00	0.16	0.16
29	6.00	12.00	-6.00	30.00	0.16	0.16
30	6.00	12.00	-6.00	30.00	0.17	0.17
31	6.00	12.00	-6.00	30.00	0.16	0.16

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID		mark cleaner	
		SIGNATURE: 	25-Dec
		5303834088	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: :

System Name: callahans	ID#: 41 91551	Month/Year: 25-Dec	Disinfection Giardia Log Inactiv: 1
------------------------	---------------	--------------------	-------------------------------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2	25.2	50.4	9.5	6.80	41.6	YES	
2	2	25.2	50.4	9.4	6.90	43.4	YES	
3	2.1	25.2	52.9	9.3	6.80	42.6	YES	
4	2	25.2	50.4	9.4	6.70	40.4	YES	
5	2.1	25.2	52.9	9.5	6.80	42.1	YES	
6	2	25.2	50.4	9.5	6.90	43.1	YES	
7	1.9	25.2	47.9	9.6	6.80	40.9	YES	
8	1.9	25.2	47.9	9.4	6.90	42.9	YES	
9	2	25.2	50.4	9.5	6.80	41.6	YES	
10	2.1	25.2	52.9	9.5	6.80	42.1	YES	
11	2	25.2	50.4	9.6	6.80	41.3	YES	
12	2	25.2	50.4	9.5	6.70	40.2	YES	
13	2.1	25.2	52.9	9.4	6.80	42.3	YES	
14	2	25.2	50.4	9.4	6.90	43.4	YES	
15	1.9	25.2	47.9	9.4	6.90	42.9	YES	
16	2	25.2	50.4	9.5	6.80	41.6	YES	
17	2.1	25.2	52.9	9.5	6.70	40.6	YES	
18	2.1	25.2	52.9	9.6	6.80	41.8	YES	
19	2	25.2	50.4	9.4	6.80	41.9	YES	
20	2.1	25.2	52.9	9.3	6.90	44.1	YES	
21	2	25.2	50.4	9.4	6.80	41.9	YES	
22	2	25.2	50.4	9.4	6.70	40.4	YES	
23	1.9	25.2	47.9	9.5	6.80	41.1	YES	
24	2	25.2	50.4	9.4	6.90	43.4	YES	
25	1.9	25.2	47.9	9.4	6.80	41.4	YES	
26	2.1	25.2	52.9	9.3	6.80	42.6	YES	
27	2	25.2	50.4	9.5	6.70	40.2	YES	
28	2	25.2	50.4	9.4	6.80	41.9	YES	
29	2.1	25.2	52.9	9.4	6.90	43.8	YES	
30	2	25.2	50.4	9.3	6.80	42.1	YES	
31	2	25.2	50.4	9.4	6.80	41.9	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350