

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Jackson
Month/Year: 01/28/28

Cartridge or Bag Filtration

System Name:	Callahane		ID#:	41 91551	WTP ID:	TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day * [NTU]
1	6.00	12.00	-6.00	30.00	0.15	0.15
2	6.00	12.00	-6.00	30.00	0.15	0.15
3	6.00	12.00	-6.00	30.00	0.16	0.16
4	6.00	12.00	-6.00	30.00	0.15	0.15
5	6.00	12.00	-6.00	30.00	0.16	0.16
6	6.00	12.00	-6.00	30.00	0.15	0.15
7	6.00	12.00	-6.00	30.00	0.15	0.15
8	6.00	12.00	-6.00	30.00	0.14	0.14
9	6.00	12.00	-6.00	30.00	0.15	0.15
10	6.00	12.00	-6.00	30.00	0.16	0.16
11	6.00	12.00	-6.00	30.00	0.16	0.16
12	6.00	12.00	-6.00	30.00	0.15	0.15
13	6.00	12.00	-6.00	30.00	0.16	0.16
14	6.00	12.00	-6.00	30.00	0.14	0.14
15	6.00	12.00	-6.00	30.00	0.15	0.15
16	6.00	12.00	-6.00	30.00	0.15	0.15
17	6.00	12.00	-6.00	30.00	0.15	0.15
18	6.00	12.00	-6.00	30.00	0.14	0.14
19	6.00	12.00	-6.00	30.00	0.16	0.16
20	6.00	12.00	-6.00	30.00	0.15	0.15
21	6.00	12.00	-6.00	30.00	0.15	0.15
22	6.00	12.00	-6.00	30.00	0.16	0.16
23	6.00	12.00	-6.00	30.00	0.15	0.15
24	6.00	12.00	-6.00	30.00	0.15	0.15
25	6.00	12.00	-6.00	30.00	0.16	0.16
26	6.00	12.00	-6.00	30.00	0.17	0.17
27	6.00	12.00	-6.00	30.00	0.16	0.16
28	6.00	12.00	-6.00	30.00	0.15	0.15
29	6.00	12.00	-6.00	30.00	0.16	0.16
30	6.00	12.00	-6.00	30.00	0.15	0.15
31	6.00	12.00	-6.00	30.00	0.14	0.14

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes/No	Cl's met everyday? (see back)	Yes/No
All daily turbidity readings ≤ 5 NTU?	Yes/No		Yes/No
Note: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		mark cleaner	
		SIGNATURE:	02/01/28
		530383-4088	CERT #:

* Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: :

System Name:	callahane	ID#: 41	91551	Month/Year:	01/01/26	Disinfection Byproduct Log Inactive:	1
--------------	-----------	---------	-------	-------------	----------	--------------------------------------	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? *	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[C]		formula	Yes / No	[GPM]
1	2	25.2	50.4	9.5	6.80	41.6	YES	
2	2.1	25.2	52.9	9.6	6.80	41.8	YES	
3	2.2	25.2	55.4	9.6	6.90	43.8	YES	
4	2.1	25.2	52.9	9.7	6.90	43.0	YES	
5	2.1	25.2	52.9	9.7	6.80	41.5	YES	
6	2.1	25.2	52.9	9.7	6.80	41.5	YES	
7	2	25.2	50.4	9.7	6.70	39.6	YES	
8	2	25.2	50.4	9.8	6.80	40.8	YES	
9	2	25.2	50.4	9.8	6.80	40.8	YES	
10	2.1	25.2	52.9	9.7	6.80	41.5	YES	
11	2	25.2	50.4	9.8	6.80	40.8	YES	
12	2	25.2	50.4	9.7	6.80	41.0	YES	
13	1.9	25.2	47.9	9.8	6.70	39.0	YES	
14	2	25.2	50.4	9.8	6.80	40.8	YES	
15	2	25.2	50.4	9.8	6.90	42.2	YES	
16	2.1	25.2	52.9	9.9	6.80	41.0	YES	
17	2.1	25.2	52.9	9.8	6.70	39.8	YES	
18	2	25.2	50.4	9.8	6.80	40.8	YES	
19	2.1	25.2	52.9	10.0	6.80	40.7	YES	
20	2	25.2	50.4	9.9	6.70	39.1	YES	
21	2	25.2	50.4	10.0	6.70	38.9	YES	
22	1.9	25.2	47.9	9.9	6.80	40.1	YES	
23	1.9	25.2	47.9	9.9	6.80	40.1	YES	
24	2	25.2	50.4	10.0	6.80	40.3	YES	
25	2	25.2	50.4	9.9	6.70	39.1	YES	
26	1.9	25.2	47.9	9.8	6.80	40.3	YES	
27	1.9	25.2	47.9	9.9	6.80	40.1	YES	
28	2	25.2	50.4	10.0	6.90	41.7	YES	
29	2.1	25.2	52.9	10.0	6.80	40.7	YES	
30	2.1	25.2	52.9	10.1	6.80	40.4	YES	
31	2.1	25.2	52.9	10.0	6.90	42.2	YES	

* If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.