

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Jackson

Cartridge or Bag Filtration

Month/Year: Feb-26

System Name:	callahans		ID#:	41 91551	WTP ID:	TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	6.00	12.00	-6.00	30.00	0.15	0.15
2	6.00	12.00	-6.00	30.00	0.16	0.16
3	6.00	12.00	-6.00	30.00	0.16	0.16
4	6.00	12.00	-6.00	30.00	0.17	0.17
5	6.00	12.00	-6.00	30.00	0.16	0.16
6	6.00	12.00	-6.00	30.00	0.15	0.15
7	6.00	12.00	-6.00	30.00	0.15	0.15
8	6.00	12.00	-6.00	30.00	0.15	0.15
9	6.00	12.00	-6.00	30.00	0.15	0.15
10	6.00	12.00	-6.00	30.00	0.14	0.14
11	6.00	12.00	-6.00	30.00	0.16	0.16
12	6.00	12.00	-6.00	30.00	0.15	0.15
13	6.00	12.00	-6.00	30.00	0.14	0.14
14	6.00	12.00	-6.00	30.00	0.15	0.15
15	6.00	12.00	-6.00	30.00	0.14	0.14
16	6.00	12.00	-6.00	30.00	0.15	0.15
17	6.00	12.00	-6.00	30.00	0.16	0.16
18	6.00	12.00	-6.00	30.00	0.15	0.15
19	6.00	12.00	-6.00	30.00	0.15	0.15
20	6.00	12.00	-6.00	30.00	0.14	0.14
21	6.00	12.00	-6.00	30.00	0.16	0.16
22	6.00	12.00	-6.00	30.00	0.15	0.15
23	6.00	12.00	-6.00	30.00	0.16	0.16
24	6.00	12.00	-6.00	30.00	0.15	0.15
25	6.00	12.00	-6.00	30.00	0.15	0.15
26	6.00	12.00	-6.00	30.00	0.14	0.14
27	6.00	12.00	-6.00	30.00	0.15	0.15
28	6.00	12.00	-6.00	30.00	0.16	0.16
29						
30						
31						

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No
<p>Notes: PSI = pounds per square inch</p> <p>PSID = pounds per square inch difference (before filter - after filter)</p> <p>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.</p>		<p>mark cleaner</p> <p>SIGNATURE: _____</p> <p>5303834088 CERT #: _____</p>	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : OHA

System Name:

callahans

ID#: 41

91551

feb 2026

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2	25.2	50.4	9.5	6.50	37.5	YES	
2	2	25.2	50.4	9.6	6.50	37.2	YES	
3	1.9	25.2	47.9	9.5	6.60	38.4	YES	
4	1.9	25.2	47.9	9.7	6.50	36.6	YES	
5	1.9	25.2	47.9	9.6	6.70	39.5	YES	
6	2	25.2	50.4	9.8	6.60	38.0	YES	
7	2	25.2	50.4	9.7	6.50	37.0	YES	
8	1.9	25.2	47.9	9.8	6.50	36.4	YES	
9	1.8	25.2	45.4	9.6	6.60	37.7	YES	
10	2.1	25.2	52.9	9.7	6.60	38.7	YES	
11	2.1	25.2	52.9	9.7	6.60	38.7	YES	
12	2	25.2	50.4	9.8	6.50	36.8	YES	
13	2	25.2	50.4	9.9	6.50	36.5	YES	
14	2.1	25.2	52.9	9.8	6.60	38.5	YES	
15	2.1	25.2	52.9	9.8	6.50	37.2	YES	
16	2	25.2	50.4	9.9	6.50	36.5	YES	
17	2.1	25.2	52.9	9.8	6.60	38.5	YES	
18	2.1	25.2	52.9	9.8	6.60	38.5	YES	
19	2	25.2	50.4	9.7	6.60	38.3	YES	
20	1.9	25.2	47.9	9.8	6.50	36.4	YES	
21	2	25.2	50.4	9.9	6.60	37.8	YES	
22	2.1	25.2	52.9	9.8	6.70	39.8	YES	
23	2	25.2	50.4	9.9	6.60	37.8	YES	
24	2	25.2	50.4	9.8	6.50	36.8	YES	
25	2	25.2	50.4	9.7	6.60	38.3	YES	
26	2.1	25.2	52.9	9.8	6.60	38.5	YES	
27	1.9	25.2	47.9	9.9	6.50	36.1	YES	
28	2	25.2	50.4	9.9	6.60	37.8	YES	
29								
30								
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350