

OHA - Drinking Water Services – Turbidity Monitoring Report Form County:

System Name: *Cascade Google Prop* ID #: _____ WTP-: _____ Month/Year: *1/21*

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.029						
2	.025						
3	.041						
4	.031						
5	.037						
6	.035						
7	.034						
8	.029						
9	.038						
10	.033						
11	.028						
12	.030						
13	.045						
14	.051						
15	.032						
16	.039						
17	.040						
18	.034						
19	.029						
20	.023						
21	.018						
22	.034						
23	.041						
24	.027						
25	.032						
26	.018						
27	.020						
28	.025						
29	.027						
30	.026						
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² Yes / No All daily turbidity readings ≤ 5 NTU? Yes / No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No
Notes:	PRINTED NAME: <i>Steve Lolandi</i>	DATE: <i>2-8-21</i>
	SIGNATURE: <i>[Signature]</i>	CERT #:
	PHONE #: <i>(541) 560 3333</i>	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: Cascade Goose Prop ID #: _____ WTP: _____ Month/Year: 1-121

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/19A	.8	35	28	7.4	6.15	824	✓	40
2/12N	.8		28	7.2	6.15	824	✓	
3/12N	.7		24.5	7.6	6.17	824	✓	
4/11A	.9		31.5	8.8	6.17	18	✓	
5/1A	.9		31.5	8.2	6.16	18	✓	
6/10A	.8		28	8.4	6.16	18	✓	
7/11A	.8		28	7.7	6.15	18	✓	
8/19A	.8		28	8.2	6.15	18	✓	
9/11A	1.0		35	7.6	6.14	18	✓	
10/12N	1.0		35	7.8	6.15	18	✓	
11/11A	.7		24.5	8.2	6.16	18	✓	
12/12P	.9		31.5	8.6	6.10	19	✓	
13/13P	1.0		35	8.8	6.14	19	✓	
14/12N	1.0		35	8.2	6.13	19	✓	
15/19A	.9		31.5	9.2	6.12	19	✓	
16/12M	.8		28	9.7	6.13	19	✓	
17/11P	.9		31.5	9.4	6.13	19	✓	
18/18A	.8		28	8.7	6.12	19	✓	
19/19A	.8		28	8.9	6.12	19	✓	
20/14P	.7		24.5	8.9	6.11	19	✓	
21/12P	1.5		52.5	7.6	6.11	20	✓	
22/18A	1.3		45.5	7.1	6.11	25	✓	
23/12N	1.3		45.5	7.4	6.11	25	✓	
24/19A	1.0		35.0	6.7	6.10	25	✓	
25/19A	1.0		35	5.9	6.10	25	✓	
26/19A	.9		32.5	4.9	6.10	25	✓	
27/11P	1.5		52.5	5.7	6.12	26	✓	
28/11A	1.4		49	6.3	6.12	26	✓	
29/19A	1.0		35	5.9	6.12	26	✓	
30/11A	1.3		46.5	7.1	6.12	25	✓	
31/12N	1.3		46.5	7.9	6.12	19	✓	

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf