


OHA - Drinking Water Services – Turbidity Monitoring Report Form County:

System Name: *Cascade Google Prop* ID #:  WTP-: Month/Year:

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.029						
2	.027						
3	.029						
4	.019						
5	.015						
6	.019						
7	.016						
8	.015						
9	.027						
10	.030						
11	.021						
12	.028						
13	.137						
14	.171						
15	.049						
16	.032						
17	.033						
18	.040						
19	.042						
20	.032						
21	.018						
22	.015						
23	.017						
24	.015						
25	.016						
26	.023						
27	.016						
28	.020						
29	.016						
30	.019						
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: <i>Steve Lolandi</i>	
		SIGNATURE: <i>Steve Lolandi</i>	DATE: <i>5-2-21</i>
		PHONE #: <i>(541) 560 3333</i>	CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: Cascade Goose Prop ID #: _____ WTP: _____ Month/Year: 4 21

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/10 ^A	0.8	35	31.5	9.5	6.26	18	✓	40
2/10 ^A	1.0		35.0	10.2	6.26	18	✓	
3/10 ^A	1.0		35	11.5	6.29	18	✓	
4/10 ^A	1.4		49	11.4	6.31	19	✓	
5/11 ^P	1.2		42	11.2	6.32	19	✓	
6/10 ^A	1.1		38.5	12.2	6.32	19	✓	
7/13 ^P	1.1		38.5	12.7	6.33	19	✓	
8/19 ^A	1.0		35	12.5	6.33	19	✓	
9/18 ^A	1.0		35	11.10	6.34	19	✓	
10/18 ^A	1.0		35	11.0	6.33	19	✓	
11/12 ^P	.9		31.5	12.2	6.34	19	✓	
12/15 ^A	.9		31.5	12.9	6.35	19	✓	
13/12 ^P	.8		28	12.9	6.35	19	✓	
14/13 ^P	.6		21	14.5	6.42	12	✓	
15/10 ^A	.7		24.5	15.2	6.43	12	✓	
16/11 ^A	1.3		45.5	13.6	6.44	19	✓	
17/19 ^A	1.1		38.5	14.2	6.44	19	✓	
18/19 ^A	1.1		38.5	13.9	6.45	12	✓	
19/10 ^A	1.0		35	14.9	6.45	12	✓	
20/11 ^A	1.0		35	14.2	6.45	12	✓	
21/10 ^A	.7		24.5	14.5	6.46	12	✓	
22/12 ^P	1.0		35	14.3	6.47	13	✓	
23/13 ^P	1.0		35	14.9	6.47	13	✓	
24/16 ^P	.9		31.5	13.9	6.47	13	✓	
25/12 ^N	.9		31.5	13.7	6.47	13	✓	
26/12 ^N	1.0		35	12.9	6.49	12	✓	
27/19 ^A	1.5		52.5	12.2	6.50	19	✓	
28/12 ^P	1.2		42	12.7	6.50	12	✓	
29/19 ^A	1.0		35	14.0	6.48	13	✓	
30/12 ^N	1.0		35	14.7	6.48	13	✓	
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf