

OHA - Drinking Water Services - Turbidity Monitoring Report Form County:



System Name: Cascade Gorge Prop ID #: \_\_\_\_\_ WTP-: \_\_\_\_\_ Month/Year: 5/2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	.020						
2	.018						
3	.021						
4	.020						
5	.020						
6	.037						
7	.042						
8	.029						
9	.024						
10	.019						
11	.020						
12	.022						
13	.023						
14	.020						
15	.018						
16	.025						
17	.027						
18	.029						
19	.026						
20	.028						
21	.031						
22	.030						
23	.029						
24	.084						
25	.040						
26	.031						
27	.032						
28	.029						
29	.030						
30	.030						
31	.031						

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b> 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / No	<b>Monthly Summary (Answer Yes or No)</b>	
	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
<b>Notes:</b>	PRINTED NAME: <u>Steve Lolandi</u>	
	SIGNATURE: <u>[Signature]</u>	DATE: <u>5-31-21</u>
	PHONE #: <u>(541) 560 3333</u>	CERT #: _____

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name:

Cascade Goose Prop

ID #:

WTP-:

Month/Year:

5 21

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
11/12 <sup>N</sup>	1.1	38.5	38.5	14.4	6.49	13	✓	40
21/12 <sup>W</sup>	1.1	38.5	38.5	14.7	6.48	13	✓	
31/3 <sup>P</sup>	1.0		35	13.9	6.49	13	✓	
41/10 <sup>A</sup>	1.0		35	14.2	6.49	13	✓	
51/3 <sup>P</sup>	.9		32.5	14.9	6.50	13	✓	
61/2 <sup>P</sup>	.9		32.5	15.7	6.51	13	✓	
71/4 <sup>P</sup>	.8		28	17.2	6.51	12	✓	
81/4 <sup>P</sup>	.7		24.5	16.7	6.51	12	✓	
91/5 <sup>P</sup>	.7		24.5	16.9	6.52	12	✓	
101/12 <sup>N</sup>	.9		32.5	15.8	6.52	12	✓	
111/12 <sup>N</sup>	1.0		35	15.2	6.53	13	✓	
121/5 <sup>P</sup>	1.0		35	16.5	6.53	13	✓	
131/4 <sup>D</sup>	.9		32.5	16.9	6.53	13	✓	
141/1 <sup>A</sup>	.9		32.5	18.4	6.54	13	✓	
151/3 <sup>A</sup>	1.0		35	17.2	6.54	13	✓	
161/3 <sup>P</sup>	.7		24.5	17.2	6.54	12	✓	
171/4 <sup>P</sup>	1.0		35	18.2	6.55	9	✓	
181/1 <sup>P</sup>	1.0		35	17.8	6.55	9	✓	
191/10 <sup>A</sup>	1.0		35	16.6	6.53	13	✓	
201/7 <sup>P</sup>	.9		32.5	16.9	6.54	13	✓	
211/3 <sup>P</sup>	.7		24.5	15.5	6.56	12	✓	
221/12 <sup>N</sup>	.6		21	15.9	6.57	12	✓	
231/5 <sup>P</sup>	1.0		35	16.1	6.58	13	✓	
241/2 <sup>P</sup>	1.3		45	16.9	6.60	13	✓	
251/12 <sup>N</sup>	1.0		35	16.2	6.60	13	✓	
261/7 <sup>A</sup>	1.1		38.5	17.2	6.61	13	✓	
271/4 <sup>P</sup>	1.0		35	16.9	6.60	13	✓	
281/9 <sup>A</sup>	.7		24.5	16.8	6.60	12	✓	
291/11 <sup>A</sup>	.9		32.5	16.4	6.58	12	✓	
301/12 <sup>N</sup>	.9		32.5	16.7	6.59	12	✓	
311/10 <sup>A</sup>	1.1		38.5	17.6	6.59	9	✓	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours.

Revised October 2013