


OHA - Drinking Water Services – Turbidity Monitoring Report Form County:

System Name: *Cascade Google Prop* ID #:  WTP-: Month/Year: *6/2021*

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.022						
2	.040						
3	.030						
4	.032						
5	.033						
6	.032						
7	.028						
8	.028						
9	.027						
10	.028						
11	.065						
12	.061						
13	.049						
14	.032						
15	.034						
16	.030						
17	.024						
18	.030						
19	.033						
20	.030						
21	.029						
22	.030						
23	.029						
24	.037						
25	.029						
26	.030						
27	.029						
28	.030						
29	.037						
30	.030						
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes / No All daily turbidity readings ≤ 5 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No
Notes:	PRINTED NAME: <i>Steve Lolandi</i>	
	SIGNATURE:	DATE: <i>6/30/2021</i>
	PHONE #: <i>(541) 560 3333</i>	CERT #:

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services – Surface Water Quality Data Form

System Name: Cascade Goose Prop ID #: _____ WTP: _____ Month/Year: 6/2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
11/9 ^A	1.0	35	35	18.2	6.40	6.609	✓	40
2/10 ^A	1.0		35	19.3	6.58	6.589	✓	
3/8 ^A	.9		32.5	20.1	6.59	6.5912	✓	
4/8 ^A	.9		32.5	19.9	6.55	6.5512	✓	
5/8 ^A	.9		32.5	18.8	6.56	6.568	✓	
6/8 ^A	.7		24.5	18.2	6.54	6.548	✓	
7/8 ^A	1.0		35	16.9	6.54	6.5411	✓	
8/8 ^A	.8		28	16.8	6.55	6.5511	✓	
9/8 ^A	1.0		35	16.3	6.56	11	✓	
10/8 ^A	1.3		45.5	15.8	6.57	11	✓	
11/8 ^A	1.1		38.5	16.5	6.56	11	✓	
12/8 ^A	1.0		35	16.2	6.57	11	✓	
13/8 ^A	1.0		35	15.4	6.57	11	✓	
14/8 ^A	.5		17.5	18.1	6.57	8	✓	
15/8 ^A	.5		17.5	17.7	6.59	8	✓	
16/8 ^A	.5		17.5	17.2	6.56	8	✓	
17/8 ^A	.6		17.8	17.7	6.57	8	✓	
18/8 ^A	1.0		35	18.6	6.57	9	✓	
19/8 ^A	1.2		42	19.0	6.54	10	✓	
20/8 ^A	1.0		35	19.7	6.57	9	✓	
21/8 ^A	1.0		35	20.1	6.57	9	✓	
22/8 ^A	1.0		35	21.5	6.15	9	✓	
23/8 ^A	1.1		38.5	21.1	6.55	9	✓	
24/8 ^A	.7		24.5	22.9	6.56	9	✓	
25/9 ^A	1.1		38.5	21.4	6.54	9	✓	
26/9 ^A	1.0		35	21.9	6.54	9	✓	
27/10 ^A	1.0		35	22.9	6.56	9	✓	
28/11 ^A	1.0		35	23.7	6.55	9	✓	
29/	.7		24.5	23.8	6.54	6	✓	
30/	1.0		35	22.8	6.54	9	✓	
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-ait-unfiltered.pdf