

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Jackson

Cartridge or Bag Filtration

Month/Year: 01/01/23

System Name:		Cascade Gorge Properties		ID#: 91556	WTP ID: TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU] Highest Reading of the day ¹ [NTU]
1	45.00	45.00			0.01	
2	45.00	45.00			0.01	
3	45.00	45.00	0.00		0.01	
4	45.00	45.00	0.00		0.01	
5	45.00	45.00	0.00		0.01	
6	45.00	45.00	0.00		0.01	
7	45.00	45.00	0.00		0.01	
8	45.00	45.00	0.00		0.01	
9	45.00	45.00	0.00		0.01	
10	45.00	45.00	0.00		0.01	
11	45.00	45.00	0.00		0.01	
12	45.00	45.00	0.00		0.01	
13	45.00	45.00	0.00		0.01	
14	45.00	45.00	0.00		0.01	
15	45.00	45.00	0.00		0.01	
16	45.00	45.00	0.00		0.01	
17	45.00	45.00	0.00		0.01	
18	45.00	45.00	0.00		0.01	
19	45.00	45.00	0.00		0.01	
20	45.00	45.00	0.00		0.01	
21	45.00	45.00	0.00		0.01	
22	45.00	45.00	0.00		0.01	
23	45.00	45.00	0.00		0.01	
24	45.00	45.00	0.00		0.01	
25	45.00	45.00	0.00		0.01	
26	45.00	45.00	0.00		0.01	
27	45.00	45.00	0.00		0.01	
28	45.00	45.00	0.00		0.01	
29	45.00	45.00	0.00		0.01	
30	45.00	45.00	0.00		0.01	
31	45.00	45.00	0.00		0.01	
Cartridge & Bag Filtration					Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?			Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?			Yes	Yes	YES	
Notes: PSI = pounds per square inch					PRINTED NAME:	
PSID = pounds per square inch difference (before filter - after filter)					Samantha Schaafsma	
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.					02/02/23	
					5415603248	
					CERT #:	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	ID#: 41	Month/Year:	Disinfection Giardia Log Inactiv:	1
---------------------	----------------	--------------------	--	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ² Minimum Cl ₂ Residual at 1st User (C) ² Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T) Contact Time (T) Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ² CT Met? ² CT Met? Met? 2	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.8	207	372.6	6.0		7.6	Yes	
2	1.8	207	372.6	6.1		7.6	Yes	
3	1.5	207	310.5	5.5		7.6	YES	
4	1.5	207	310.5	6.8		7.3	YES	
5	1.5	207	310.5	7.8		7.1	YES	
6	1.8	207	372.6	7.5		7.2	YES	
7	1.7	207	351.9	7.4		7.2	YES	
8	2	207	414.0	7.9		7.2	YES	
9	2	207	414.0	7.8		7.2	YES	
10	2	207	414.0	7.9		7.2	YES	
11	2	207	414.0	7.5		7.3	YES	
12	2	207	414.0	8.9		7.0	YES	
13	1.5	207	310.5	9.0		6.8	YES	
14	1.5	207	310.5	8.9		6.8	YES	
15	1.5	207	310.5	7.5		7.1	YES	
16	1.5	207	310.5	7.8		7.1	YES	
17	2.3	207	476.1	8.8		7.1	YES	
18	2	207	414.0	5.4		7.8	YES	
19	2	207	414.0	6.1		7.6	YES	
20	2	207	414.0	6.0		7.7	YES	
21	2	207	414.0	6.1		7.6	YES	
22	2	207	414.0	6.0		7.7	YES	
23	2	207	414.0	7.5		7.3	YES	
24	2	207	414.0	6.1		7.6	YES	
25	2	207	414.0	6.2		7.6	YES	
26	2.5	207	517.5	6.6		7.7	YES	
27	2.5	207	517.5	5.2		8.1	YES	
28	2.5	207	517.5	5.6		8.0	YES	
29	2.3	207	476.1	5.5		7.9	YES	
30	2	207	414.0	5.6		7.8	YES	
31	2	207	414.0	6.1		7.6	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.