

OHA - Drinking Water Services – Turbidity Monitoring Report Form County:

System Name: *Cascade Gorge Prop* ID #: _____ WTP-: _____ Month/Year: *3-21*

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.018						
2	.017						
3	.019						
4	.022						
5	.021						
6	.026						
7	.020						
8	.021						
9	.021						
10	.016						
11	.017						
12	.016						
13	.253						
14	.021						
15	.025						
16	.024						
17	.043						
18	.035						
19	.029						
20	.030						
21	.029						
22	.034						
23	.076						
24	.065						
25	.054						
26	.050						
27	.043						
28	.039						
29	.038						
30	.032						
31	.029						

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes / No	All daily turbidity readings ≤ 5 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No
Notes:		PRINTED NAME: <i>Steve Lolandi</i>	DATE: <i>3-31</i>
		SIGNATURE: <i>Steve Lolandi</i>	CERT #:
		PHONE #: <i>(541) 560 3333</i>	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: *Cascade Goose Prop* ID #: _____ WTP: _____ Month/Year: *8 21*

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1110A	1.2	35	42	6.5	6.13	25	✓	40
219A	1.1		38.5	6.6	6.14	24	✓	
3112N	1.0		35	7.2	6.14	24	✓	
411P	1.0		35	7.4	6.14	24	✓	
518A	.9		31.5	7.3	6.14	24	✓	
614P	.9		31.5	7.8	6.14	18	✓	
7112N	1.0		35	7.9	6.14	18	✓	
8112N	1.1		38.5	8.2	6.15	19	✓	
9112W	1.0		35	8.2	6.16	18	✓	
1016P	.9		31.5	8.8	6.17	18	✓	
1111P	.9		31.5	8.6	6.17	18	✓	
1218A	1.0		35	7.9	6.17	18	✓	
13112W	.8		28	7.8	6.16	18	✓	
14112W	.8		28	8.2	6.16	18	✓	
15111A	1.0		35	8.1	6.18	19	✓	
1612A	1.0		35	8.4	6.20	19	✓	
1719A	.9		31.5	8.4	6.21	18	✓	
1819A	.9		31.5	9.2	6.21	18	✓	
19111A	1.0		35	8.9	6.22	19	✓	
20110A	1.0		35	8.8	6.21	19	✓	
21111A	.8		28	8.7	6.22	18	✓	
2219A	.7		24.5	8.2	6.21	18	✓	
23111A	.7		24.5	8.5	6.22	18	✓	
24111A	.6		21	8.8	6.23	18	✓	
25111A	.6		21	8.8	6.24	18	✓	
2613P	.7		24.5	9.2	6.24	18	✓	
27111A	1.0		35	8.4	6.25	18	✓	
2814P	1.0		35	8.9	6.25	18	✓	
2911P	.9		31.5	9.0	6.26	18	✓	
3018A	.9		31.5	8.7	6.26	18	✓	
31110A	1.0		35	9.3	6.26	18	✓	

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013
 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf